

**UIAZC.E343624****Flame Detectors, Fire Alarm, for Use in Hazardous Locations**[Page Bottom](#)

Flame Detectors, Fire Alarm, for Use in Hazardous Locations

[See General Information for Flame Detectors, Fire Alarm, for Use in Hazardous Locations](#)

MINE SAFETY APPLIANCES CO

E343624

1000 CRANBERRY WOODS DR

CRANBERRY TOWNSHIP, PA 16066 USA

Multi-Spectral Infrared Flame Detectors: Model FlameGard 5 MSIR, Part Nos. 71296-10, -11, -12, -13, -14, -15, -28, -29, -30, -31, -32, -33, Input: 20-36 V dc, 120 mA, suitable for use in outdoor and/or hazardous locations, Class I, Groups B, C and D; Class II, Groups E, F and G; Class III.

[Last Updated](#) on 2011-07-21

[Questions?](#)[Print this page](#)[Notice of Disclaimer](#)[Page Top](#)

[Copyright © 2011 Underwriters Laboratories of Canada Inc.](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2011 Underwriters Laboratories of Canada Inc."

An independent organization working for a safer world with integrity, precision and knowledge.

