



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

COMBUSTIBLE GAS DETECTORS, Fixed

Stationary single channel 4-20mA combustible gas detector. Standalone infrared Sensor/Transmitter. PrimaX IR is Explosionproof for Class I, Division 1, Groups A, B, C and D, T4A Ta= -50°C to +75°C; and Dust-ignitionproof for Class II, Division 1, Groups E, F and G, T4A Ta = -50°C to +75°C Hazardous (Classified) Locations, indoor and outdoor, Type 4X. The PrimaX IR includes a male ¾ NPT connection for field installation. The PrimaX IR provides a 4-20mA measurement signal with HART communication. The electrical ratings are 18 - 32 VDC, 6 watts maximum. The operating temperature range of the PrimaX IR is -50°C to +75°C. The PrimaX IR monitors 0-100% LEL methane gas-in-air atmospheres or 0-100% LEL propane gas-in-air atmospheres. In addition, the apparatus complies with FM6320 Performance Requirements for Combustible Gas Detectors.

The following accessories may be used with the PrimaX IR Gas Detector: Aluminum junction box kit, p/n 10117607; Stainless steel junction box kit, p/n 10124331; Calibration cover/bump cap, p/n 10122228; Flow cap, p/n 10113100; Environmental guard, p/n 10113663; Calibration Cap 10111874.

Specifications - The manufacturer's specifications are as follows:

Operating Temperature:	-50°C to +75°C
Storage Temperature:	-40°C to +80°C
Relative Humidity:	15 to 95% RH
Supply Parameters:	18-32 Vdc, 24 Vdc (Nominal), 6 watts maximum
Measurement Signal:	4-20mA
Calibration:	Calibration Cap or HART

A-PRIMAXIR-abc, Gas Monitor

a = Gas type: 14 or 15

b = NPT thread

c = -50°C to +75°C

FM Approved for:

Mine Safety Appliance Co
Cranberry Twp, PA United States



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3615	2006
Class 3810	2005
Class 6320	2000
ANSI/NEMA 250	1991


Original Project ID: 3036837

Approval Granted: June 28, 2013

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC



 J.E. Marquedant
 Group Manager, Electrical

28 June 2013

 Date