



防爆合格证

CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证号
Certificate No. CE14.5030

产品名称
Name of Product

ANN 智能超声波气体泄漏检测仪

型号及规格
Type of Product

GASSONIC OBSERVER-i

防爆标志
Marking

Ex d ia II B+H₂ T6 Gb; DIP A21 Ta 85°C

技术文件
Technical Documents

/

图号
Drawing No.

805568

备注
Note (s)

1. 环境温度-40°C ≤ Ta ≤ +60°C。
2. 产品外壳防护等级为 IP66。
3. 制造商: General Monitors Ireland Ltd
4. 制造商地址: Ballybrit Business Park, Galway, Ireland

经对上述产品图样及技术文件的审查和样品的检验,其符合以下标准:

By verifying the drawings and technical documents and checking samples, the product complies with the following standards:

GB3836.1-2010 GB3836.2-2010 GB3836.4-2010 GB12476.1-2000

发给:
Issued to:

梅思安(中国)安全设备有限公司

本证失效日期:
Date of Expire:

2019-06-23

发证日期:
Date of Issue:

2014-06-23

中心印章
Center seal



中心主任
Director

梅思安

石油和化学工业电气产品防爆质量监督检验中心
Supervision & Test Center of Ex-products of China Petroleum & Chemical Industry

注:本证仅对与送检样品一致的产品有效。

Note: This certificate is only valid for the products that are in accord with sample(s) tested and verified.

中心地址:中国天津市丁字沽三号路85号

Center Add: No.85 No.3 Road DingZiGu Tianjin China Post code: 300131

E-mail:cec@pcec.com.cn

邮政编码:300131

电话/传真:022-26651066/26689116

Tel/Fax: 022-26651066/26689116

http://www.pcec.com.cn