



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: **IECEX SIR 16.0096** Page 1 of 4 Certificate history:  
Status: **Current** Issue No: 5 Issue 4 (2019-04-26)  
Date of Issue: 2020-06-11 Issue 3 (2018-03-21)  
Issue 2 (2017-05-23)  
Issue 1 (2016-12-23)  
Issue 0 (2016-10-25)

Applicant: **MSA - The Safety Company**  
1000 Cranberry Woods Dr  
Cranberry Township, PA 16066-5296  
**United States of America**

Equipment: **ALTAIR 4XR Multi Gas Detector**

Optional accessory:

Type of Protection: **Flameproof and Intrinsically Safe**

Marking: **With XCell Ex Sensor**  
Ex da ia IIC T4 Ga  
IEC 60079-29-1  
Ta = -40°C to +60°C  
Ex ia I Ma  
Ta = -40°C to +60°C  
**Without XCell Ex Sensor**  
Ex ia IIC T4 Ga  
Ta = -40°C to +60°C  
Ex ia I Ma  
Ta = -40°C to +60°C

Note: IEC 60079-29-1 applies to Group II only.

Approved for issue on behalf of the IECEx  
Certification Body:

**N Jones**

Position:

**Certification Manager**

Signature:  
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting [www.iecex.com](http://www.iecex.com) or use of this QR Code.



Certificate issued by:

**SIRA Certification Service**  
**CSA Group**  
**Unit 6, Hawarden Industrial Park**  
**Hawarden, Deeside, CH5 3US**  
**United Kingdom**





# IECEX Certificate of Conformity

Certificate No.: **IECEX SIR 16.0096**

Page 2 of 4

Date of issue: 2020-06-11

Issue No: 5

Manufacturer: **MSA - The Safety Company**  
1000 Cranberry Woods Dr  
Cranberry Township, PA 16066-5296  
**United States of America**

Additional  
manufacturing  
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

## STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

**IEC 60079-0:2011** Explosive atmospheres - Part 0: General requirements  
Edition:6.0

**IEC 60079-1:2014-06** Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"  
Edition:7.0

**IEC 60079-11:2011** Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"  
Edition:6.0

**IEC 60079-26:2014-10** Explosive atmospheres – Part 26: Equipment with Equipment Protection Level (EPL) Ga  
Edition:3.0

**IEC 60079-29-1:2007** Explosive Atmospheres - Part 29-1: Gas Detectors - Performance requirements of detectors for flammable gases  
Edition:1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

## TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[GB/SIR/ExTR16.0248/00](#)  
[GB/SIR/ExTR18.0050/00](#)

[GB/SIR/ExTR16.0329/00](#)  
[GB/SIR/ExTR19.0123/00](#)

[GB/SIR/ExTR17.0073/00](#)  
[GB/SIR/ExTR20.0090/00](#)

Quality Assessment Report:

[FR/INE/QAR08.0011/10](#)



# IECEx Certificate of Conformity

Certificate No.: **IECEx SIR 16.0096**

Page 3 of 4

Date of issue: 2020-06-11

Issue No: 5

## **EQUIPMENT:**

Equipment and systems covered by this Certificate are as follows:

The MSA ALTAIR® 4XR is a handheld, battery operated, Multi-gas Detector with Bluetooth capabilities that can measure between 1 and 4 gases using a combination of the following MSA XCell® Sensors: one catalytic-bead combustible cell, one oxygen electrochemical cell and one dual toxic electrochemical cell. The enclosure is rectangular in shape, includes an LCD display window, and is manufactured from a non-metallic material with an overmold. There is an external connection that is only used for charging the battery and shall only be connected when located in a non-hazardous location.

Powered by a rechargeable Lithium Ion Polymer Battery Cell, Sony model US503759A8H, rated 3.8 V (nominal), 1400 mAh (nominal). MSA assembly number 10083913.

Performance temperature range: -20°C to +60°C as specified in Altair 4XR Addendum A manual 10175895.

## **Conditions of manufacture**

The Manufacturer shall comply with the following:

1. The ALTAIR 4XR incorporates previously certified sensors. It is therefore the responsibility of the manufacturer to continually monitor the status of the certification associated with this device. The manufacturer shall inform Sira of any modifications to the device that may impinge upon the explosion safety design of the ALTAIR 4XR.

**SPECIFIC CONDITIONS OF USE: NO**



# IECEx Certificate of Conformity

Certificate No.: **IECEx SIR 16.0096**

Page 4 of 4

Date of issue: 2020-06-11

Issue No: 5

## **DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)**

This issue, issue 5, recognises the following change: refer to the certificate annex to view a comprehensive history:

1. Recognise an update to the firmware (R 2.27) within the Altair 4XR; the firmware change confirmed as having no effect on the gas measuring functions or safety aspects of the instrument.
2. Introduction of a new resin material for the calibration cap, RTP 2599 X 133889, to replace the obsolete resin material RTP 2599 X 97420D.
3. Introduction of an alternate sensor filter material, Cobetter PFOY-T1DT, to replace the obsolete filter material Versapor 1200R Hydrophobic.
4. Recognise an update to the firmware (R 2.28) within the Altair 4XR; the firmware change confirmed as having no effect on the gas measuring functions or safety aspects of the instrument.
5. Recognise a correction to the markings in Issue 4 of the Certificate due to a typographical error.
6. Equipment Description revised to recognizes: "Performance temperature range: -20°C to +60°C as specified in Altair 4XR Addendum A manual 10175895."

## **Annex:**

[IECEx SIR 16.0096 Iss 5 Annexe\\_1.pdf](#)

Annexe to: IECEx SIR 16.0096 Issue 5  
Applicant: MSA - THE SAFETY COMPANY  
Apparatus: ALTAIR 4XR multi gas detector

---



## Full certificate change history

**Issue 1** – this Issue introduced the following change:

1. Update the method of protection marking to reflect the change from “d” to “da” on the latest XCell Ex sensor certificates.

**Issue 2** – this Issue introduced the following change:

1. It was recognised that these gas detectors have been subjected to the performance test requirements of IEC 60079-29-1:2007 Edition 1.

**Issue 3** – this Issue introduced the following change:

1. The detector was allowed to be used for mining applications; as a consequence, the following marking was recognised:

**With XCell Ex Sensor**

Ex ia I Ma

Ta = -40°C to +60°C

**Without XCell Ex Sensor**

Ex ia I Ma

Ta = -40°C to +60°C

**Issue 4** – this Issue introduced the following change:

1. Introduction of IEC 60079-26:2014 Edition 3, following the appropriate assessment to demonstrate compliance with the latest technical knowledge; IEC 60079-26:2014 Edition 3 was added to the list of standards.
2. Recognises a correction to the marking; to remove “da” from Without XCell Ex Sensor.

**Issue 5** – this Issue introduced the following change:

1. Recognise an update to the firmware (R 2.27) within the Altair 4XR; the firmware change confirmed as having no effect on the gas measuring functions or safety aspects of the instrument.
2. Introduction of a new resin material for the calibration cap, RTP 2599 X 133889, to replace the obsolete resin material RTP 2599 X 97420D.
3. Introduction of an alternate sensor filter material, Cobetter PFOY-T1DT, to replace the obsolete filter material Versapor 1200R Hydrophobic.
4. Recognise an update to the firmware (R 2.28) within the Altair 4XR; the firmware change confirmed as having no effect on the gas measuring functions or safety aspects of the instrument.
5. Recognise a correction to the markings in Issue 4 of the Certificate due to a typographical error.
6. Equipment Description revised to recognizes: “Performance temperature range: -20°C to +60°C as specified in Altair 4XR Addendum A manual 10175895.”