



Certificate of Compliance

Certificate: 70102917 **Master Contract:** 167534 (064969_0_000)

Project: 70195025 **Date Issued:** 2018-09-24

Issued to: MSA - The Safety Company
1000 Cranberry Woods Dr.
Cranberry Township, Pennsylvania 16066-5296
USA
Attention: Johnny Lee

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: *Dimcho Genov*
Dimcho Genov

PRODUCTS

CLASS - C225206 - PROCESS CONTROL EQUIPMENT

CLASS - C225286 - PROCESS CONTROL EQUIPMENT-Certified to US Standards

Refrigerant leakage detector, model Chillgard 5000

Rated 100 – 240 Vac, 50/60Hz, 200VA max; relay contacts 250Vac / 24Vdc, 8A rms

Notes:

1. The above model is permanently connected, Pollution Degree 2, Measurement Category II.
2. Mode of operation: Continuous
3. Environmental Conditions: 0 to 50 C, 2975m max



Certificate: 70102917

Project: 70195025

Master Contract: 167534

Date Issued: 2018-09-24

APPLICABLE REQUIREMENTS

CSA Standards:

CAN/CSA-C22.2 No. 61010-1-12

- Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

UL Standards:

UL Std. No. 61010-1 (3rd Edition)

- Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements