
Effective 1 January 2016

26776 Simpatica Circle Lake Forest, CA 92630 Telephone:+1-949-581-4464

www.MSAsafety.com/detection Email: info.gm@MSAsafety.com



MODEL 4802A 02A SERIES COMBUSTIBLE GAS CONTROLLER



CONTROL MODULE:

(Std) 4802A 02A SERIES COMBUSTIBLE GAS CONTROLLER

A. RELAYS/OUTPUT:

4802A

B. RELAY-STATE-NC:

LATCH ALARM (A2), NON-LATCH WARN (A1), DE-ENERGIZED 1- □ (Std) LATCH ALARM (A2), NON-LATCH WARN (A1), ENERGIZED 2- 🗆 LATCH ALARM (A2), LATCH WARN (A1), DE-ENERGIZED 3- □ LATCH ALARM (A2), LATCH WARN (A1), ENERGIZED 4- □ NON-LATCH ALARM (A2), NON-LATCH WARN (A1), DE-ENERGIZED 5- □ 6- □ NON-LATCH ALARM (A2), NON-LATCH WARN (A1), ENERGIZED NON-LATCH ALARM (A2), LATCH WARN (A1), DE-ENERGIZED 7- 🗆 NON-LATCH ALARM (A2), LATCH WARN (A1), ENERGIZED 8- 🗆

C. COMBUSTIBLE-SENSOR: (price per active channel)

00- □ (Std) NONE

D. CARD-TEST/RAMP-TIME:

1- \(\text{(Std)} \) INHIBITED RELAYS - 3 SECOND RAMP TIME 2- \(\text{INHIBITED RELAYS} - 10 SECOND RAMP TIME 3- \(\text{ACTIVATE RELAYS} - 3 SECOND RAMP TIME 4- \(\text{ACTIVATE RELAYS} - 10 SECOND RAMP TIME

E. INHIBIT/COMPATIBLE:

1- □ (Std) FAULT NOT ACTIVE/CAL, FUA OUTPUTS
2- □ FAULT NOT ACTIVE/COMPATIBLE
3- □ FAULT ACTIVE/CAL, FUA OUTPUTS
4- □ FAULT ACTIVE/COMPATIBLE

F. SENSOR-HOUSING: (price per active channel)

0- □ (Std) NONE

G. APPROVALS/LANGUAGE:

1- □ (Std) FM/CSA

2- □ CE AND RUSSIAN WITH RUSSIAN NAMEPLATE
3- □ CE/ATEX-GMIL WITH ENGLISH NAMEPLATE

4- □ ENGLISH GMI ATEX

5-

CE ONLY WITH ENGLISH NAMEPLATE-GMIL

5-3