



Certificate of Compliance

Certificate: 1553900 (LR 25993-15,-17)

Master Contract: 161129

Project: 1701866

Date Issued: 2005/08/15

Issued to: General Monitors, Incorporated

26776 Simpatica Cir
Lake Forest, CA 92630
USA

Attention: Regina Bolotin

The products listed below are eligible to bear the CSA Mark shown



Issued by: Glenn Black

Authorized by: Nick Alfano, Operations
Manager

PRODUCTS

CLASS 4828 01 - SIGNAL APPLIANCES - - Combustible Gas Detection Instruments-For
Hazardous Locations

Class I, Groups B, C and D:

Combustible gas monitoring systems, Model 480 and 580 (through-hole) consisting of control unit, rack, panel, wall or cabinet mounting in non-hazardous areas, Model 480 (single channel), rated input 117V ac, 50/60Hz or 24V dc, 12.5W; contacts 117V ac, 50/60Hz or 24V dc, 3A (res.) or Model 580 (dual channel), rated input 117V ac, 50/60Hz or 24V dc, 18.5W; contacts 117V ac, 50/60Hz or 24V dc, 3A (res.) and remote sensors for use in hazardous locations, CSA Certified, P/N 10001-1, 10001-1R, 10014-1, 10015-1, 10022-1, 10058-1, 10058-1R, 10059-1, 11159-1 or 10164-1 ; connected to an explosion-proof enclosure, Part No 10252.



Certificate: 1553900 (LR 25993-15,-17)

Master Contract: 161129

Project: 1701866

Date Issued: 2005/08/15

Combustible gas monitoring systems, Model 480A and 580A (SMT construction) consisting of control unit, rack, panel, wall or cabinet mounting in non-hazardous areas, Model 480A (single channel), rated input 117/230Vac, 50/60Hz or 24Vdc, 12.5W; contacts 117/230Vac, 50/60Hz or 24Vdc, 4A (res.) or Model 580A (dual channel), rated input 117/230Vac, 50/60Hz or 24Vdc, 18.5W; contacts 117/230Vac, 50/60Hz or 24V dc, 4A (res.) and remote sensors for use in hazardous locations, CSA Certified, P/N 10001-1, 10001-1R, 10014-1, 10015-1, 10022-1, 10058-1, 10058-1R, 10059-1, 11159-1 or 10164-1 ; connected to an explosion-proof enclosure, Part No 10252.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 142-M1987 - Process Control Equipment

CSA Std C22.2 No. 152-M1984 - Combustible Gas Detection Instruments

MARKINGS

- Company Name
- Model number
- Serial number
- Electrical rating
- CSA Monogram
- Reference to installation instructions
- "CAUTION: RE MOUNTING OUTSIDE OF HAZARDOUS AREA".
- CAUTION: Read and understand manual before operating
- The words " C22.2 No. 152 "