

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1725 - CPR – E0001

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

FL4000H

produced by or for

General Monitors

26776 Simpatica Cr.
Lake Forest, CA. USA

and produced in the manufacturing plant(s)

General Monitors Inc.

26776 Simpatica Cr.
Lake Forest, CA. 92630
USA

General Monitors Ireland

Ballybrit Business Park
Galway, Ireland

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-10:2002 +A1:2005 – Flame Detectors – Point Detectors

under system 1 for the performances set out in this certificate (see Approval Report 0003052470 for detail) are applied and that

the construction product fulfils all the prescribed requirements for these performances.

Sensitivities:

The High and Medium settings both meet Class 1 of EN 54-10:2002+A1:2005
The Low setting meets Class 2 of EN 54-10:2002+A1:2005

This certificate was first issued on 23rd June 2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performances of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.