



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

System Description – FL500

Approval Guide Listing: Category:

- Electrical Signaling Alarm Signal Initiating Devices Fire Detection, Flame-Actuated
- Hazardous Location Equipment - United States Detectors Flame

General Monitors Inc
 26776 Simpatica Cr
 Lake Forest, CA 92630
 United States

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standards and other documents:

| <i>Approval Standards</i> | | <i>Other Standards</i> | |
|---------------------------|-------------|----------------------------------|-------------|
| <i>Class Number</i> | <i>Date</i> | <i>Organization, Designation</i> | <i>Date</i> |
| 3260 | 2018 | ANSI/ NFPA 72 | 2013 |
| 3600 | 2018 | | |
| 3615 | 2018 | | |
| 3616 | 2011 | | |

Original Approval Job Identification: PR449306

Approval Granted: August 27, 2018

Related Report:

Subsequent Revisions:

To verify the availability of the Approved product, please refer to www.approvalguide.com

J.E. Marquedant
 J.E. Marquedant
 VP, Manager of Electrical Systems
 FM Approvals
 1151 Boston-Providence Turnpike,
 Norwood MA, 02062 USA

27 August 2018

Date



Member of the FM Global Group



Certificate of Compliance

Approval Guide Listing:

- ☑ Electrical Signaling ☑ Alarm Signal Initiating Devices ☑ Fire Detection, Flame-Actuated
- ☑ Hazardous Location Equipment - United States ☑ Detectors ☑ Flame

The FL500 UV/IR Flame Detector is Approved for use:

| | |
|-------------------------------------|--|
| Hazardous Location Equipment | XP//I/ABCD/T5 DIP//II, III/1/EFG/T5 -50°C ≤ Ta ≤ +85°C |
|-------------------------------------|--|

Operating Voltage: 24Vdc [20 to 36Vdc]
 Current draw: 200mA max. during COPM only, typical 80mA – 150mA
 Dry contact Form C SPDT relay outputs: 250 VAC, 30VDC, 5A
 Operating temperature and humidity range is -50°C to +85°C (-67°F to +185°F), 0-95 %RH
 4-20mA Outputs:

- Fault 0 – 0.2mA,
- COPM Fault 2mA,
- Ready, 4mA
- IR signal 8mA
- UV signal 12mA
- Alarm low signal 16mA
- Alarm high signal 20mA

Compatible Approved control panel for alarm and trouble reporting.

Sensitivity settings: High, Medium, Low

FL500 Flame Simulator: not FM Approvals examined

Firmware: version 0

Fuels: see below table

Detection times on axis at high sensitivity:

| Fuel | Distance (feet) | Response Time (s) |
|-----------|-----------------|-------------------|
| n-Heptane | 90 | 6 |
| | 60 | 2.7 |
| Methanol | 40 | 12 |
| Methane | 80 | 9.9 |
| Propane | 60 | 6.5 |
| Butane | 55 | 5.5 |
| Ethane | 60 | 2.1 |



Member of the FM Global Group