



The Safety Company

1000 Cranberry Woods Drive,  
Cranberry Township, PA 16066

**MSA Declaration of Conformity**  
In Accordance with ANSI/ISEA 125-2014  
IAC-23-056 - Z04 Rev 0

**Statement of Conformity:** MSA declares that the  
ArcSafe Lanyards  
is in conformity with the requirements of

ASTM F887-05

| Product Code | Model / Part Numbers Covered   |
|--------------|--|
| IAC-23-056   | 10060139, 10060140, 10060284, 10088253, 10088255, 10088256, 10088257, 10107200, 10107202, 10118808, 10118809, 10118810, 10126527 |

ANSI/ISEA 125-2014 conformity assessment method:  Level 1  Level 2

For Level 2, information about ISO 17025-accredited facility in which the product was tested:

Intertek The test facility is an independent 3rd Party

The test facility is owned or partially owned by an entity within supplier's corporate structure, or within the manufacturing stream for this product, including subcontractors

| Report | Test Facility Used: | Test Facility Document # |
|--------|---------------------|--------------------------|
| 1      | Intertek            | 3098837-001              |
| 2      | Intertek            | 3098837-001              |

For additional information about this product(s), please contact MSA Customer Service at 1-800-MSA-2222. When requesting information, please reference model number(s).

Quality Assurance:

Jim Wonderling

Date: 1/26/2015  
1/20/2015

# Performance Details

Revision 0

| Report | Standard and Product Requirements   | Results                                   | Pass / Fail |
|--------|---|---|-------------|
| 1, 2   | 22.8.1 No electric arc ignition as defined by Specification F1891.  | ArcSafe Lanyard meets these requirements. | Pass        |
| 1, 2   | 22.8.2 No melting and dripping as defined by Specificalion F1891.   | ArcSafe Lanyard meets these requirements. | Pass        |
| 1, 2   | 22.8.3 Pass specified drop test after electric arc exposure defined above (22.7 The exposed test specifmens shall be exposed to required drop test (reference ANSI/ASSE Z359.1 or ANSI/ASSE Z359.13 as applicable (See Note 3))), after the arc exposure as soon as is practially possible. | ArcSafe Lanyard meets these requirements. | Pass        |
| 1, 2   | 22.8.4 No greater than 5 s of afterflame as defined by Specification F1891.   | ArcSafe Lanyard meets these requirements. | Pass        |