



Certificate of Compliance to IEC 61508

FM Approvals
Certifies herewith that the

Multi-point Combustible Gas Monitor
 Model IR4000M
 (Safety Manual [MANIRSAFETY])

Complies with the relevant requirements of standards listed below:

Standards	Description	Compliance
IEC 61508-1 2010	Functional Safety of Electronic/Electrical/Programmable Electronic Safety-Related Systems- General Requirements	Part 1
IEC 61508-2 2010	Functional Safety of Electronic/Electrical/Programmable Electronic Safety-Related Systems	Part 2
IEC 61508-3-2010	Functional Safety of Electronic/Electrical/Programmable Electronic Safety-Related Systems- Software Requirements	Part 3

And therefore

IS DECLARED "FIT FOR USE" IN A SIL 2 or 1
1oo1 Low Demand SAFETY APPLICATION

Models	SIL	HFT	SFF	PFD	λ_s	λ_{DD}	λ_{DU}
IR4000M	2 or 1	0	98%	4.3×10^{-5}	1.5×10^{-6}	1.63×10^{-6}	3.29×10^{-8}

*This certificate is subject to conditions of use presented in FM Approval Report
 Project ID 3034949, 3055292*

J.E. Marquedant
 J.E. Marquedant
 Manager of Electrical Systems
 FM Approvals
 1151 Boston-Providence Turnpike,
 Norwood MA, 02062 USA

18 May 2015

 Date



Member of the FM Global Group

General Monitors Inc
 26776 Simpatica Cr
 Lake Forest, CA 92630
 United States