

CEKTIFICATE OF CONFORMITY

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT PER US REQUIREMENTS

Certificate No: 1.

FM17CA0021

Equipment:

(Type Reference and Name)

GAS DETECTORS (COMBUSTIBLE)

IR400 and IR4000 series

Name of Listing Company: 3.

Address of Listing Company:

General Monitors

26776 Simpatica Circle Lake Forest, CA 92630 USA

The examination and test results are recorded in confidential report number:

3029222 dated 9th July 2008

FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

CSA-C22.2 No 0.5: 2008, CSA-C22.2 No 213: 1987, CSA/CAN C22.2 No 30: 2003, CSA/CAN C22.2 No 142: 2000, CSA/CAN C22.2 No 152: 1984

- If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
- This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.
- **Equipment Ratings:**

IR400: Suitable for installation in Class I, Division 1, 2 Groups B, C and D, indoor/outdoor (TYPE 4X, IP65) hazardous locations, T5, Ta = -40°C to +75°C

IR4000M/S: Suitable for installation in Class I, Division 1, 2 Groups B, C and D, and Class I, Zone 1, IIB +H2; indoor/outdoor (TYPE 4X) hazardous locations, T5 Ta = -40°C to +75°C

Certificate issued by:

J. E. Marguedant

Manager, Electrical Systems

2 Marquedia

17 April 2017

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Tumpike, Norwood, MA 02062 USA T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 347 (Mar 16) Page 1 of 3

SCHEDULE



US Certificate Of Conformity No: FM17CA0021

10. The marking of the equipment shall include:

IR400: Class I, Division 1, 2 Groups B, C and D, TYPE 4X, IP65 T5 Ta = -40°C to +75°C IR4000M/S: Class I, Division 1, 2 Groups B, C and D, and Class I, Zone 1, IIB +H2, TYPE 4X, T5 Ta = -40°C to +75°C

11. Description of Equipment:

IR400 - Stationary Single Channel 4-20mA, Modbus, or Hart Combustible Gas Detector. Stand Alone Sensor/Transmitter model IR400. IR400 is suitable for installation in Class I, Division 1, 2 Groups B, C and D, indoor/outdoor (TYPE 4X, IP65) hazardous locations with a temperature class of T5, Ta = -40°C to +75°C and may be connected to the IR4000M, IR4000S or junction box P/N 31305. The IR400 monitors 0-100% LEL of either; methane, propane, hexane, pentane, ethane, or butane. The IR400 provides a 4-20mA output. The operating voltage range is 20-36 Vdc, with a maximum power consumption of 4.8W. The apparatus complies with ANSI/ISA-12.13.01-2000; Performance Requirements for Combustible Gas Detectors. This Approval covers use of the instruments when connected to FM Approvals stand alone combustible gas control unit and when calibration is performed using the gas to be monitored and when the higher of the alarm points is preset within 10% LEL of the calibration gas concentration.

32500-2

a: 1, 2, 5 through 8, 11, 12, 15, 16, 17, 18, 21 through 32, 65, 68, 86, 100, 101

31305-a a: 1, 2, 3 or 4

IR4000S/M - Stationary single or dual channel Control Unit for Combustible Gas Detectors. Stationary single or dual channel Control Unit for Combustible Gas Detectors. Stand alone controller model IR4000M and IR4000S monitor FM Approved Combustible Gas Detectors which monitor 0-100% LEL gas-in-air atmospheres. Suitable for installation in Class I, Division 1, 2 Groups B, C and D, and Class I, Zone 1, IIB +H₂; indoor/outdoor (TYPE 4X) hazardous locations with a temperature class of T5 Ta = -40°C to +75°C. The IR4000M and IR4000S controllers' operating temperature range is -40°C to +75°C and operating voltage is 24VDC at 2W. The apparatus also complies with ANSI/ISA-12.13.01-2000; Performance Requirements for Combustible Gas Detectors. This Approval covers use of the instruments when connected to FM Approvals stand alone combustible gas detector and when calibration is performed using the gas to be monitored and when the higher of the alarm points is preset within 10% LEL of the calibration gas concentration.

325a-b

a= Controller model: 63 or 80

b= Monitor Output: 1, 2, 3, 4, 5, 6, 7, 8, 9*, 10*, 11*, 12*, 13*, 14*, 15*, 16*, 39

* = only available when a=80

12. Specific Conditions of Use:

None

13. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals US Certification Requirements.

14. Schedule Drawings

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Tumpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 347 (Mar 16) Page 2 of 3

SCHEDULE



US Certificate Of Conformity No: FM17CA0021

A copy of the technical documentation has been kept by FM Approvals.

15. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
9 th July 2008	Original Issue.
19 th February 2017	Supplement 4: Report Reference: RR207859 dated 19th February 2017 Decription of the Change: Addition of enclosure 31305 to description and conversion to new format.
17 th April 2017	Supplement 5: Report Reference: 3057599 dated 17 th April 2017 Description of the Change: Hardware, Firmware and documentation update.



THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Tumpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com