

TYPE APPROVAL CERTIFICATE**This is to certify:****That the Gas Detector**with type designation(s)
ULTIMA X5000 Gas Monitor

Issued to

MSA - The Safety Company
Cranberry Twp, PA, USAis found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Location classes:**

Temperature	D; Tested to -40°C
Humidity	B
Vibration	A
EMC	B
Enclosure	C /IP66; B /IP65 for Digital Sensor

Issued at **Høvik** on **2019-11-27**This Certificate is valid until **2023-10-23**.DNV GL local station: **Certification & Inspection Services**Approval Engineer: **Nils Jarem**for **DNV GL**

Trond Sjøvåg
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: **262.1-027984-2**
Certificate No: **TAA00001R9**
Revision No: **1**

Product description

ULTIMA® X5000 Gas Monitor for detection of combustible gases.

ULTIMA® X5000 Gas Monitor consisting of ULTIMA® X5000 transmitter, X5000 Junction Box, ULTIMA® XIR Plus point IR sensor or catalytic Point Digital Sensor for combustible gases.

The ULTIMA® X5000 Gas Monitor supports two Digital Sensors installed either integral to the ULTIMA® X5000 transmitter or remotely using the X5000 Junction Box, one ULTIMA® XIR Plus point IR detector and one Digital Sensor installed either integral to the ULTIMA® X5000 transmitter or remotely using the X5000 Junction Box, or two ULTIMA® XIR Plus point IR detector installed remotely using the X5000 Junction Box.

The ULTIMA® X5000 Gas Monitor generates two independent discrete analog outputs; one for each sensor connected to the transmitter. The analog output associated with Sensor 1 also has the digital HART (Highway Addressable Remote Transducer) communication superimposed on the analog signal. If two sensors are connected, the digital HART communication carries information for both sensors. The ULTIMA® X5000 also has a Bluetooth communication option. Bluetooth is used for status inquiry and setup.

Place of manufacture

Digital Sensor:
General Monitors, CA, USA

XIR Plus:
MSA - The Safety Company
Cranberry Twp, PA. USA

X5000 Transmitter and Junction Box:
MSA - The Safety Company
Cranberry Twp, PA. USA

General Monitors Ireland LTD.
Galway, Ireland

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Application/Limitation

Ex-certification is not covered by this certificate. Application in hazardous area to be approved in each case according to the Rules and Ex-Certification/ Special Condition for Safe Use listed in valid Ex-certificate issued by a notified/recognized Certification Body.

Type Approval documentation

Scope	Doc. No.	Description
IEC 60079-29-1	R70116274A rev. 2017-09	Assessment report
	R70199267A rev. 2019-08	Assessment report EN60079-29-1:2016
EN 50271	R70220416 rev.1.0/2019-08-16	Assessment Report, X5000 EN 50271:2010.
IEC 60092-504	1604-077E rev. D	EMI TEST REPORT X5000 GAS DETECTION SYSTEM
	1806-107E rev. B	EMI TEST REPORT X5000 GAS DETECTOR
	1806-108N rev. A	ENVIRONMENTAL TEST REPORT X5000
IEC 60533	1807-166N rev. B	ENVIRONMENTAL TEST REPORT X5000

Job Id: **262.1-027984-2**
Certificate No: **TAA00001R9**
Revision No: **1**

Scope	Doc. No.	Description
	1807-077N rev. A	Salt mist TEST TRANSMITTERS WITH SENSORS
	1807-078N rev. A	ENV. TEST REPORT TRANSMITTERS WITH SENSORS
Manual	10177361 rev. 05	Operating Manual ULTIMA® X5000 Gas Monitor
Manual	10182779 rev. 05	Addendum to Operating Manual 10177361
Product data	ID 0720-185-MC rev. 2018-02	Ultima X5000 gas monitor data sheet-EN
Drawing	SK3015-1051 rev 4	INSTALLATION OUTLINE ULTIMA X5000

Type approval initial assessment report, Cranberry, PA, 2018-03-07.

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, November 2016.
Applicable tests according to EN 60079-29-1:2016.

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE