



SAFETY MANUAL

ULTIMA® MOS-5

Intelligent Sensor for Hydrogen Sulfide Gas Detection



The information and technical data disclosed in this document may be used and disseminated only for the purposes and to the extent specifically authorized in writing by MSA.

Safety Manual

MSA reserves the right to change published specifications and designs without prior notice.

Part No.
Revision

MANMOS5SAFETY
00

Safety Manual – ULTIMA MOS-5 Intelligent Sensor for H₂S Gas Detection

This manual describes the safety related information for the installation, operation, configuration, and maintenance of the following field devices:

- ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection
- ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications

For complete information regarding performance, installation, operation, maintenance and specifications of the above products, please refer to the associated product manual.

MSA's mission is to benefit society by providing solutions through industry-leading safety products, services and systems that save lives and protect capital resources from the dangers of hazardous flames, gases and vapors.

The safety products you have purchased should be handled carefully and installed, calibrated, and maintained in accordance with the associated product instruction manual. Remember, these products are for your safety.



WARNING: TOXIC, COMBUSTIBLE, AND FLAMMABLE GASES AND VAPORS ARE VERY DANGEROUS. USE EXTREME CAUTION WHEN THESE HAZARDS ARE PRESENT.

INTRODUCTION

General Description

The ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection and the ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications are microprocessor-based transmitters designed for use with MSA's metal oxide semiconductor (MOS) sensors. They provide a 4-20 mA signal which is proportional to 0 to 100% of the detection range at the H₂S sensor. Optional Warn and Alarm relays can be programmed to trip when gas concentrations reach a percentage of the sensor range. All detectors are regarded as Type B field devices per IEC 61508.

The safety function of the ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection does not include:

- HART communication
- RS-485 Modbus communication

The safety function of the ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications does not include:

- RS-485 Modbus communication

HART and Modbus communication are typically used for field device setup, diagnostics, and troubleshooting. Be sure to observe requirements for interfacing in hazardous locations. HART and Modbus communication are non-interfering functions and do not interrupt the safety critical function of the detectors.

INSTALLATION

NOTE: Power should remain disconnected until all other wiring connections are made.

For complete installation information for the ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection and the ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications, refer to the product instruction manual for each of these field devices.

Detector Location Considerations

There are no standard rules for detector placement, since the optimum detector location varies with the application. The customer must evaluate conditions at the facility to make this determination. To the greatest extent possible, the ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection and the ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications should be installed in a manner that provides accessibility to conduct occasional calibration checks.

The sensors used in the ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection and the ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications should be mounted pointing down to prevent water build-up on the sensor head. Furthermore, the sensor should not be placed where contaminating substances may coat it or where excessive vibration is possible.

Although the ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection and the ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications are Radio Frequency Interference (RFI) resistant, the units should not be mounted close to radio transmitters, high magnetic or electrical fields, or in areas with similar interference.

Locate the ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection and the ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications where prevailing air currents contain the maximum concentration of gas. Also, locate the detectors as near as possible to the likely source of a gas leak. Observe the temperature range of the field device and locate the unit away from concentrated sources of heat. Do not locate the intelligent sensors in areas that exceed the maximum operating temperature of the unit, such as locations with gas turbine exhaust.

No special or additional mounting, wiring, power, or tool requirements exist beyond the standard installation practices documented in the product instruction manuals for the ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection and the ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications.

Sensors may be adversely affected by prolonged exposure to certain materials. Loss of sensitivity or corrosion may be gradual if such materials are present in low concentrations, or it may be rapid at high concentrations. Examples of these substances are as follows:

- Silicones (often contained in greases and aerosols)
- Halides, compounds containing fluorine, chlorine, bromine, and iodine
- Heavy metals, e.g., tetraethyl lead
- Caustic and acidic liquids and vapors

- Glycol

The presence of poisons and contaminants in an area does not necessarily preclude the use of an ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection and the ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications. The feasibility of using a sensor in such areas must be determined by an analysis of the specific factors in each application and MSA should be consulted before attempting any such installation.

Sensors used in these areas usually require more frequent calibration checks than normal, and typically have a shorter life. In many such applications, the standard two-year warranty would not apply.



WARNING: Under NO circumstances should equipment be connected or disconnected when under power. This is contrary to hazardous area regulations and may also lead to serious damage to the equipment. Equipment damaged in this manner is not covered under warranty.

OPERATION, CONFIGURATION AND MAINTENANCE

For complete information on the operation, configuration, and maintenance of the ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection and the ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications, refer to the product instruction manual for each field device.

MSA recommends that the ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection and the ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications be calibrated one hour after start-up and again 24 hours after initial start-up, and that the calibration be checked every ninety (90) days to ensure system integrity. More frequent calibration checks are recommended for environments that have a greater likelihood of mud collecting on the sensor head, sensors accidentally being painted over, or other conditions that may adversely impact the sensor.

MSA recommends that a calibration schedule be established and followed. A logbook should also be kept, showing calibration dates and dates of sensor replacement.

The ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection and the ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications are intelligent sensors performing internal diagnostics on critical faults every second and respond with 0 mA at the Analog Output upon detection of a fault. In addition, depending on configuration, the ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection may also respond with a fault signal of 1.25 mA or 3.5 mA at the Analog Output.

Refer to the Troubleshooting Section in the appropriate product instruction manual in the event of a calibration or operational fault. Spare parts should be on-hand as described in the Spare Parts Section of the product instruction manual.

NOTE: Entering Gas Check or Calibration mode sends a 1.5 mA output signal and disables the Warning and Alarm relay circuits. The ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications output for these modes is selectable (0 mA, 1.5 mA, or 2 mA) with 1.5 mA as the default.



WARNING: Disconnect or inhibit external devices such as Trip Amplifiers, Programmable Logic Controllers (PLC), or Distributed Control Systems (DCS) before performing any maintenance.

SPECIFICATIONS

Table 1 and Table 2 list specifications for the ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection and the ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications. For a complete list of specifications, refer to the instruction manual of each respective model.

	ULTIMA MOS-5 Intelligent Sensor with HART Communication for H ₂ S Gas Detection	ULTIMA MOS-5E Intelligent Sensor for H ₂ S Gas Detection for European Applications
Instruction Manual P/N	MANMOS5	MANMOS5E
Temp. Range (Electronics)*		
Operating:	CSA -40°C to +75°C (-40°F to 167°F) FM -40°F to 158°F (-40°C to +60°C) ATEX -40°F to 158°F (-40°C to +70°C)	-50°C to +70°C
Storage:	-58°F to 185°F (-50°C to +85°C)	-50°C to +70°C
Humidity Range:	5% to 100% RH, non-condensing	5% to 100% RH, non-condensing
Atmosphere:	Will not operate in <5% oxygen	Will not operate in <5% oxygen
Input Power:		
Absolute min:	20 VDC	18.5 VDC
Nominal:	24 VDC	
Absolute max:	36 VDC	35 VDC

Table 1 – Environmental/Electrical Specifications

* For operating temperature range of sensors see instruction manual.

Mode	ULTIMA MOS-5 HART Disabled	ULTIMA MOS-5 HART Enabled	ULTIMA MOS-5E
Fault	0 mA	3.5 mA/ 1.25 mA**	0 mA
Calibration, Gas Check, Setup Mode	1.5 mA	3.5 mA/ 1.5 mA**	0 mA, 1.5 mA***, or 2 mA
0 – 100 % LEL	4 – 20 mA	4 – 20 mA	4 – 20 mA
Over range	20-22 mA	20 – 21.7 mA	20.1 – 22 mA

Table 2 – Analog Output Specifications*

- * See product instruction manual for analog output signal load resistance specification.
- ** ULTIMA MOS-5 HART Enabled units may have Analog Output modified to output 3.5 mA or 1.25mA for a malfunction and 3.5 mA or 1.5 mA for calibration, gas check and setup modes. The default is 3.5mA.
- ***User selectable on the ULTIMA MOS-5E for these modes. Default is 1.5 mA.

CERTIFICATIONS AND FAILURE RATE DATA

The ULTIMA MOS-5 Intelligent Sensor with HART Communication for H₂S Gas Detection and the ULTIMA MOS-5E Intelligent Sensor for H₂S Gas Detection for European Applications field devices have gone through rigorous reliability and functional safety assessments, which have resulted in each of these products being certified to IEC 61508 Parts 1, 2, and 3, by FM Approvals. The reliability assessment is a failure rate prediction that assumes an average temperature of 40°C and an environmental factor equivalent to Ground Fixed. It is assumed that the field devices will be installed in a Safety Instrumented System (SIS) operating in a Low Demand environment per IEC 61508. The tables below list the SIL parameters for each field device.

	ULTIMA MOS-5 (4-20 mA Output)	ULTIMA MOS-5 (Relay Output)
FM Certificate	XXXXX ULTIMA MOS-5	XXXXX ULTIMA MOS-5
Product Life (Years)*	22	22
λ_{DD} (Fails per hour)	1.74E-5	1.76E-5
λ_{DU} (Fails per hour)	8.83E-8	3.26E-7
Safe Failure Fraction (SFF)	>99%	98%
Safety Integrity Level (SIL)**	3	2
Diagnostic Test Interval	1 sec	1 sec
Response Time (with full scale gas applied)	<u>Screen</u> $T_{50} < 1$ minute <u>Sintered</u> $T_{50} < 2$ minutes	<u>Screen</u> $T_{50} < 1$ minute <u>Sintered</u> $T_{50} < 2$ minutes
Average Probability of Failure on Demand $PFD_{avg1001}$ ***	1.65E-4	4.2E-4

Table 3A – SIL Parameters for ULTIMA MOS-5 Detector (Clean Environment)

- * MOS sensor life is typically 3-5 years.
- ** Hardware Fault Tolerance (HFT) = 0
- *** $PFD_{avg1001}$ assumes a 4 hour repair time and 90 day proof test interval.

	ULTIMA MOS-5 (4-20 mA Output)	ULTIMA MOS-5 (Relay Output)
FM Certificate	XXXXX ULTIMA MOS-5	XXXXX ULTIMA MOS-5
Product Life (Years)*	22	22
λ_{DD} (Fails per hour)	2.5E-5	2.5E-5
λ_{DU} (Fails per hour)	2.7E-6	2.9E-6
Safe Failure Fraction (SFF)	91%	90%
Safety Integrity Level (SIL)**	2	2
Diagnostic Test Interval	1 sec	1 sec
Response Time (with full scale gas applied)	<u>Screen</u> $T_{50} < 1$ minute <u>Sintered</u> $T_{50} < 2$ minutes	<u>Screen</u> $T_{50} < 1$ minute <u>Sintered</u> $T_{50} < 2$ minutes
Average Probability of Failure on Demand $PFD_{avg1001}$ ***	3E-3	3.3E-3

Table 3B – SIL Parameters for ULTIMA MOS-5 Detector (Contaminated Environment)

- * MOS sensor life is typically 3-5 years
- ** Hardware Fault Tolerance (HFT) = 0
- *** $PFD_{avg1001}$ assumes a 4 hour repair time and 90 day proof test interval.

ULTIMA MOS-5E (4-20 mA Output)	Clean Environment	Contaminated Environment
FM Certificate	XXXXXX	XXXXXX
Product Life (Years)*	23	21
λ_{DD} (Fails per hour)	1.1E-5	1.63E-5
λ_{DU} (Fails per hour)	3.34E-8	1.83E-6
Safe Failure Fraction (SFF)	>99%	92%
Safety Integrity Level (SIL)**	3	2
Diagnostic Test Interval	1 sec	1 sec
Response Time (with full scale gas applied)	<u>Sintered</u> $T_{50} < 2$ minutes	<u>Sintered</u> $T_{50} < 2$ minutes
Average Probability of Failure on Demand $PFD_{avg} 1001^{**}$	3E-4	2.4E-3

Table 4 – SIL Parameters for ULTIMA MOS-5E Detector

* MOS sensor life is typically 3-5 years.

** Hardware Fault Tolerance (HFT) = 0

*** $PFD_{avg} 1001$ assumes a 24 hour repair time and 90 day proof test interval.

Agency Approvals

The ULTIMA MOS-5 and ULTIMA MOS-5E Detectors have the following approvals:

ULTIMA MOS-5	ULTIMA MOS-5E
CSA	ATEX
FM Approvals	IEC 61508 per FM Approvals
ATEX	
HART Registered	
IEC 61508 per FM Approvals	

Table 5 – Approvals

MSA in Europe

[www.msa-europe.com & www.msa-gasdetection.com]

Northern Europe

Netherlands

MSA Nederland

Kernweg 20
1627 LH Hoorn
Phone +31 [229] 25 03 03
Fax +31 [229] 21 13 40
info@msanet.nl

Belgium

MSA Belgium

Duwijkstraat 17
2500 Lier
Phone +32 [3] 491 91 50
Fax +32 [3] 491 91 51
msabelgium@msa.be

Great Britain

MSA Britain

Lochard House
Linnet Way
Strathclyde Business Park
BELLSHILL ML4 3RA
Scotland
Phone +44 [16 98] 57 33 57
Fax +44 [16 98] 74 0141
info@msabritain.co.uk

Sweden

MSA NORDIC

Kopparbergsgatan 29
214 44 Malmö
Phone +46 [40] 699 07 70
Fax +46 [40] 699 07 77
info@msanordic.se

MSA SORDIN

Rörläggärvägen 8
33153 Värnamo
Phone +46 [370] 69 35 50
Fax +46 [370] 69 35 55
info@sordin.se

Southern Europe

France

MSA GALLET

Zone Industrielle Sud
01400 Châtillon sur
Chalaronne
Phone +33 [474] 55 01 55
Fax +33 [474] 55 47 99
message@msa-gallet.fr

Italy

MSA Italiana

Via Po 13/17
20089 Rozzano [MI]
Phone +39 [02] 89 217 1
Fax +39 [02] 82 59 228
info-italy@msa-europe.com

Spain

MSA Española

Narcís Monturiol, 7
Pol. Ind. del Sudoeste
08960 Sant-Just Desvern
[Barcelona]
Phone +34 [93] 372 51 62
Fax +34 [93] 372 66 57
info@msa.es

Eastern Europe

Poland

MSA Safety Poland

ul. Wschodnia 5A
05-090 Raszyn k/Warszawy
Phone +48 [22] 711 50 33
Fax +48 [22] 711 50 19
eer@msa-europe.com

Czech Republic

MSA Safety Czech

Pikartská 1337/7
716 07 Ostrava-Radvanice
Phone +420 [59] 6 232222
Fax +420 [59] 6 232675
info@msa-auer.cz

Hungary

MSA Safety Hungaria

Francia út 10
1143 Budapest
Phone +36 [1] 251 34 88
Fax +36 [1] 251 46 51
info@msa.hu

Romania

MSA Safety Romania

Str. Virgil Madgearu, Nr. 5
Ap. 2, Sector 1
014135 Bucuresti
Phone +40 [21] 232 62 45
Fax +40 [21] 232 87 23
office@msanet.ro

Russia

MSA Safety Russia

Pokhodny Proezd, 14
125373 Moscow
Phone +7 [495] 921 1370/74
Fax +7 [495] 921 1368
msa-moscow@msa-europe.com

Central Europe

Germany

MSA AUER

Thiemannstrasse 1
12059 Berlin
Phone +49 [30] 68 86 0
Fax +49 [30] 68 86 15 17
info@auer.de

Austria

MSA AUER Austria

Kaplanstrasse 8
3430 Tulln
Phone +43 [22 72] 63 360
Fax +43 [22 72] 63 360 20
info@msa-auer.at

Switzerland

MSA Schweiz

Eichweg 6
8154 Oberglatt
Phone +41 [43] 255 89 00
Fax +41 [43] 255 99 90
info@msa.ch

European

International Sales

[Africa, Asia, Australia, Latin
America, Middle East]

MSA EUROPE

Thiemannstrasse 1
12059 Berlin
Phone +49 [30] 68 86 55 5
Fax +49 [30] 68 86 15 17
contact@msa-europe.com