



ULTIMA MOS-5 FIELD CONNECTIONS

NOTES: 1. DIMENSIONS SHOWN IN INCHES [MILLIMETERS].
MILLIMETER DIMENSIONS SHOWN FOR REFERENCE ONLY.
2. USE APPROVED STOPPING PLUG ONLY.

AUTHORIZED COUNTRY	MSA	MINE SAFETY APPLIANCES CO. PITTSBURGH, PA 15230, USA	THIS DRAWING IS THE PROPERTY OF MSA AND IS MADE AVAILABLE TO YOU IN CONFIDENCE AND SUBJECT TO THE FOLLOWING: NO PERMISSION IS GRANTED TO PUBLISH, USE, REPRODUCE, TRANSMIT OR DISCLOSE THIS DRAWING, OR ANY INFORMATION CONTAINED THEREIN TO OTHERS WITHOUT THE PRIOR WRITTEN CONSENT OF MSA EXCEPT FOR THE MANUFACTURE OF ARTICLES FOR MSA. SCHUTZVERMERK NACH DIN 34 BEACHTEN. MSA AUER GmbH.	DO NOT SCALE DWG.
MSA STANDARD SHOP PRACTICES APPLY		JOB NO. 3001124 PH0705	APPROVAL AGENCY CODE: NO NIOSH ATTR. DOC.:	
CRITICAL	△	DRAWN BY GJT	DATE 3-25-2011	<p>INSTALLATION OUTLINE, ULTIMA MOS-5, H2S GAS W/KIT</p> <p>CADD REF: SK3015-1042</p> <p>SCALE: 1.000</p> <p>SK3015-1042</p>
MAJOR A	△	CHECKED BY		
MAJOR B	△	PROJ. ENGR.		
100% INSPECTION	△	QUALITY ASSURANCE		
TOLERANCES UNLESS OTHERWISE SPECIFIED		MANUFACTURING		
FRACTIONAL	± 1/64			
2 PL DEC.	± 0.01			
3 PL DEC.	± 0.005			
ANGULAR	± 1 deg.			
SEE MSA STANDARD SHOP PRACTICES FOR DRILLED HOLE TOLERANCES				

LIFECYCLE STATE	REVISION
Design	A