

#### Mine Safety Appliances Company • 1000 Cranberry Woods Dr. • Cranberry Twp., PA 16066 Ultima® X Series Gas Monitors – ATO Order Form A-ULTIMA X-XP (5 6 [10] (11) Model 8 **Optional Power Supply** E = Explosion proof, with display0 = NoneI = XI (IR sensor with no display) 1 = 12 VDC Internal L = Explosion proof, no display2 = 24 VDC Internal 3 = 12 VDC External (Bracket not included) Catalytic & Electrochemical Infrared 4 = 24 VDC External (Bracket not included) NOTE: Power supplies not available for ATEX or IEC – matrix 8 J = X series junction box (No electronics) Gas Code -see list for gas type ໌9` Gas Sample Selection NOTE: The following codes will provide enclosure and 0 = None - Standard diffusion methodelectronics only. No sensor components or sensor body housing. 1 = Flow cap assemblyXE 01 = "Standard" toxics and oxygen XIR 02 = Catalytic**Integrated Accessories** 03 = IR Combustible**〔10**〕 0 = None04 = "Reactive" toxics (ex. Cl<sub>2</sub>, HCl, ClO<sub>2</sub>, NH<sub>3</sub>, HF, EtO) 1 = XP HART port $05 = IR CO_2$ (requires cable P/N 10081441 FM) Note: If $\binom{2}{1} = IR$ , $\binom{4}{1} \neq 0$ . 2 = Reset/Cal switch - approved for Div. 1, Gr.For XIR sensors use A-ULTX-SENS B-D only 3 = Both XP HART port and Reset/Cal switch (UL) Note: option 3 requires use of a HART module Configuration • A = ATEX w/metric threads **Installation Hardware** • B = ATEX w/NPTthreads **〔11**〕 0 = None\* C = CSA approval w/NPT threads 1 = Brackets> F = FM approval ( $_{c}$ FM $_{us}$ ) w/NPT threads 2 = Duct Mount Kit + U = UL approval w/NPT threads 3 = Brackets + Duct Mount Kit • I = IEC approval w/metric threads Manuals - alternate quantities can be ordered separately 〔12〕 0 = StandardSensor Output 1 = Hardcopy + CD0 = No PCBA, (Use when ordering sensor body & sensor only) 1 = 2-Wire mA output **Custom Features** 13 2 = 2-Wire (mA + HART) output 0 = None3 = 3-Wire mA output C = Custom operation necessary4 = 3-Wire ( $\underline{mA} + HAR\underline{T}$ ) output T = Custom Tagging, SSTC = Custom Tagging/Custom operations necessary Note: If $(2) = IR, (4) \neq 0$ . CC = Certificate of calibration request For XIR sensors use A-ULT-SENS **Sensor Mounting Style** S = Sensor mounted on control unitD = Sensor mounted on remote housing N = No condulet (choose for sensor/sensor body only) **Relays and LEDs** $\overline{0}$ = No relays and no LEDs (Required if 2-wire) Not permitted if 4 = 41 = LEDs, no relays (Required if Model = L) 3-wire 2 = Relays and LEDs 3-wire

### Sensor Selection Table None

- 11 Carbon Monoxide 0-100 PPM
- 12 Carbon Monoxide 0-500 PPM
- = 13 Oxygen 0- 10%
  - 14 Oxygen 0-25%
  - 15 Hydrogen Sulfide 0-10 PPM
  - 16 Hydrogen Sulfide 0-50 PPM
  - 17 Hydrogen Sulfide 0-100 PPM

# $\frac{\textbf{7}}{0 = \text{English}}$

- S = Spanish
- H = English with custom horn software

MSA # 07-20126



Mine Safety Appliances Company • 1000 Cranberry Woods Dr. • Cranberry Twp., PA 16066

- "~ 18 Chlorine 0-5 PPM
  - 20 Nitric Oxide 0-100 PPM
  - 22 Hydrogen Cyanide 0-50 PPM
- "~ 23 Hydrogen Chloride 0-50 PPM
- " ~ 24 Chlorine Dioxide 0-3 PPM
- 25 Hydrogen Sulfide 0-500PPM
- '~26 Hydrogen Fluoride 0-10 PPM
- " ~ 28 Chlorine 0-10 PPM
  - 31 Combustible gas 0-100% LEL Natural Gas & H<sub>2</sub>
  - 32 Combustible gas 0-100% LEL Petroleum Vapors
  - 33 Combustible gas 0-100% LEL Solvents
- N}"^34 Acetylene IR 0-2.5%
- N }" 35 Carbon Dioxide IR 0-0.5%
  - 36 Carbon Dioxide IR 0-2%
- N } "37 Carbon Dioxide IR 0-5%
- N \*\* 38 IR combustible 0-100% LEL- Methane
  - \*\* 39 IR combustible 0-100% LEL Propane
    - 41 Phosphine 0-2 PPM
  - 42 Arsine 0-2 PPM
  - 43 Silane 0-25 PPM
- " ~ 45 Diborane 0-50 PPM
- " ~ 46 Bromine 0-5 PPM
- "~ 47 Fluorine 0-10 PPM
- " ~ 48 Ammonia 0–100 PPM
- 49 Hydrogen 0-1000 PPM
- "~ 50 Ethylene Oxide 0-10 PPM
  - 51 Comb. Gas 0-100% LEL ATEX 4.4% CH4
  - Natural Gas and H2
  - 52 Comb. Gas 0-100% LEL ATEX 1.7% Propane
  - Petroleum Vapors
  - 53 Comb. Gas 0-100% LEL ATEX 1.7% 1.7% Propane Solvents
- "~ 54 Ammonia 0-1000 PPM
- 3 " x 55 Solvent Tolerant O2
  - 57 Carbon Monoxide 0-1000 PPM
- N 58 Comb Gas IR Methane 0-100% LEL -
  - ATEX 4.4% CH4
- N 59 Comb Gas IR Non Methane 0-100% LEL ATEX 1.7% Propane
- "~ 61 Chlorine 0-20 PPM
- 3 X 62 Solvent & CO2 Tolerant Oxygen (0 -25%)
- " x 63 Low oxygen (0 -25%)
- 3 " x 64 Low solvent tolerant oxygen (0 -25%)
  - ~ 70 Sulfur Dioxide 0-25 PPM
  - ~ 71 Sulfur Dioxide 0-100 PPM
  - ~ 72 Nitrogen Dioxide 0-10 PPM

### Selection Guide for Ultima X Combustible (Catalytic)

# CATEGORY 31: NATURAL GAS & H2 Span is set at 25% LEL with 0.6% Propane

Acetaldehyde Ethylene Methanol
Acetylene Ethylene Dichloride Methylene Chloride
Butadiene, 1, 3 Hydrogen Monomethyl Amine
Carbon Monoxide MAPP Gas Trigonox B

Ethane Methane

## CATEGORY 32: PETROLEUM VAPORS Span is set at 40% LEL with 0.6% Propane

Span is see at 10 /0 EEE with 010 /0 1 1 opane				
1, 1, 1-Trichloroethane	Cyclohexane	Pentane (n)		
Acetic Acid	Dimethoxyethane	Pentane (iso)		
Acetone	Dioxane, 1, 4	Pentene		
Acrolein	Epichlorhydrin	Propane		
Acrylonitrile	Ethanol	Propanol (n)		
Allyl chloride	Ether, Diethyl	Propanol (iso)		
Benzene	Ether, Dimethyl	Propylene		
Butane (n)	Ethylene Oxide	Propylene Oxide		
Butane (iso)	Freon 152°	Tetrahydrofuran		

Butanol (iso)	Gasoline	Toluene
Butene – 1	Hexane	Trichloroethylene
Butene - 2	Isoprene	Triethylamine
Butyl Acetate (n)	Methyl Acetate	Vinyl Acetate
Butylene	Methyl Chloride	Vinyl Chloride
Butyraldehyde	Methyl Propene (2)	
Chlorobenzene	Methyl t-Butyl Ether	

#### CATEGORY 33: GENERAL SOLVENTS Span is set at 55% LEL with 0.6% Propane

Span is set at 35 /0 LEL with 0.0 /0 I Topane			
Amyl alcohol	Ethyl Acrylate	Mthyl. Iso. Ket.	
Butanol (n)	Ethyl Benzene	Mthyl Methacrylate	
Butyl Acrylate	Heptane	Naphtha, VM&P	
Cellosolve	Hexene	Octane (iso)	
Di isopropylamine	JP - 4	Propyl Acetate	
Diethylamine	Methyl Cellosolve	Styrene	
Ethyl Acetate	Methyl Ethyl Ketone	Xylene	
If application includes gases in more than one category, specify highest number category.			

## SELECTION GUIDE FOR ULTIMA XIR COMBUSTIBLE

#### **CATEGORY 38: Methane Calibration**

	Controller	Cal	Cylinder	Cal
	_Code	Cylinder	P/N	Span Value
Methane	1	2.5% Methane	1002803	2 50% LEL

#### **CATEGORY 39: Non-Methane Calibration**

	Controller	Cal	Cylinder	Cal
	Code	<u>Cylinder</u>	P/N	Span Value
Propane	2	0.6% Propane	10028034	29% LEL
Ethane	3	0.6% Propane	10028034	25% LEL
Butane	4	0.6% Propane	10028034	28% LEL
Pentane	5	0.6% Propane	10028034	33% LEL
Hexane	6	0.6% Propane	10028034	41% LEL
Cyclopenta	ne 7	0.6% Propane	10028034	30% LEL
Ethylene	8	0.1% Propane	711054	28% LEL

For sensing multiple gases always calibrate for the least sensitive gas or vapor expected to be measured (highest response factor within category).

All other combustible gas span values available upon request.

### Key:

- UL approved, Class I, Div 1 & 2, Groups A, B, C, D;
   Class II, Div. 1, Groups E, F, G for IR, Groups F, G for E-chem and catalytic; Class III
- > FM approved Class I, Div. 1 & 2, Groups A, B, C, D for oxygen, catalytic and IR
- \* CSA approved Class I, Div. 1, Groups A, B, C & D for E-chem and catalytic, Groups B, C & D for IR
- \*\* \$530 for Ultima XL only
- ATEX or IEC approved Ex d IIc T4, IP66
- Available as custom product only
- x XP Stainless Steel only
- -- X<sup>3</sup>IR must have condulet
- Available with intrinsically safe barrier and ATEX approval or UL Div 2 approval
- " Not available as XL model
- Not available as XT model
- Not available on XPL
- Not to be used in Helium or Argon backgrounds.
   Use #62 in its place

MSA # 07-20126 REV. 0 –1 /2014