



# Ultima<sup>®</sup> X Series Gas Monitors Instruction Manual Addendum

---

CORRECTIONS:

## **Page iii, General Warnings and Cautions**

9. CSA performance Certification to standard C22.2 No. 152 is valid only when the instrument is calibrated on methane per the instruction manual.