


→ FOR DAISY-CHAIN (SERIES) WIRING OF ZGARD S SENSORS TO A CONTROLLER AS SHOWN HERE, EACH SENSOR MUST BE UNIQUELY ADDRESSED VIA SWITCHES ON SENSOR CIRCUIT BOARD.
 MAXIMUM NUMBER OF SENSORS ON THE RS-485 BUS IS 31.

NOTES:
 1. DIMENSIONS SHOWN IN INCHES (MILLIMETERS).



CHKD: DATE: Dec. 21/15 DRN: KS

Installation Outline,
 ZGARD S Multiple Protocol Output
 RS-485-MPO Output Sensors

DWG. NO.: 109130 REV. A