

## UNIT INFORMATION

Corp. 100032 January 4, 2024 LRP14HP/AC/GE/GN LRP16GE/HP

## LRP14HP/LRP14AC/LRP14GE/LRP14GN/LRP16GE/LRP16HP SERIES UNITS



## A WARNING

Improper installation, adjustment, alteration, service or maintenance can cause property damage, personal injury or loss of life. Installation and service must be performed by a licensed professional HVAC installer or equivalent, service agency, or the gas supplier.

# **A** IMPORTANT

The Clean Air Act of 1990 bans the intentional venting of refrigerant (CFCs, HCFCs and HFCs) as of July 1, 1992. Approved methods of recovery, recycling or reclaiming must be followed. Fines and/or incarceration may be levied for noncompliance.

# 

As with any mechanical equipment, contact with sharp sheet metal edges can result in personal injury. Take care while handling this equipment and wear gloves and protective clothing.

## A WARNING



Electric Shock Hazard. Can cause injury or death. Unit must be properly grounded in accordance with national and local codes.

Line voltage is present at all components when unit is not in operation on units with singlepole contactors. Disconnect all remote electric power supplies before opening access panel. Unit may have multiple power supplies.

## **Table of Contents**

Specifications – LRP14HP	2
Specifications - LRP14AC	3
Specifications - LRP14GE / LRP14GX	4
Specifications – LRP14GN	5
Specifications - LRP16GE / LRP16GX	6
Specifications – LRP16HP	7
Electric Heat Capacities – LRP14HP and AC M LRP16HP	8
Gas Heat Capacities - LRP14GE Only	8
Gas Heat Capacities - LRP16GE Only	8
Gas Heat Capacities - LRP14GN Only	8
Electrical	9
Typical Parts Arrangement	
Unit Applications	18
Blower Data – LRP14HP	23
Blower Data – LRP14AC	24
Blower Data - LRP14GE / LRP14GX	25
Blower Data – LRP14GN	26
Blower Data - LRP16GE / LRP16GX	27
Blower Data – LRP16HP	28
Wiring Diagrams and Sequence of Operation	37
LRP14GN - Heating Components and Operation.	48

The LRP14/16 series packaged units are available in sizes ranging from 2 through 5 tons (7.0 through 17.6 kW). The LRP14/16 unit is designed for HFC-410A refrigerant and for outdoor residential use only. Units can be installed at ground level or on rooftops. The LRP14 units utilize a scroll compressor. LRP16GE/GX/HP units utilize a twostage compressor. Information contained in this manual is intended for use by qualified service technicians only. All specifications are subject to change. Procedures outlined in this manual are presented as a recommendation only and do not supersede or replace local or state codes.

General Data		Model No.	LRP14HP24	LRP14HP30	LRP14HP36	LRP14HP42	LRP14HP48	LRP14HP60	
		Nominal Tonnage	2	2.5	3	3.5	4	5	
Cooling /	Cooling	Total capacity - Btuh	22,600	28,600	34,000	40,000	46,000	57,000	
Heating Performance		Total unit watts	2055	2600	3090	3635	4180	5180	
		<sup>1</sup> SEER (Btuh/Watt)	14.00	14.00	14.00	14.00	14.00	14.00	
		EER (Btuh/Watt)	11.00	11.00	11.00	11.00	11.00	11.00	
	High Temp.	Total capacity - Btuh	22,000	27,000	32,400	39,000	45,000	56,000	
	Heat	Total unit watts	1700	2140	2645	3175	3565	4440	
		COP	3.80	3.70	3.70	3.60	3.70	3.70	
	HSP	F Region IV / Region V	8.00 / 6.95	8.00 / 6.95	8.00 / 6.95	8.00 / 6.95	8.00 / 6.95	8.00 / 6.95	
	Low Temp.	Total capacity - Btuh	12,300	15,900	20,000	23,600	27,000	33,600	
	Heat	Total unit watts	1570	2025	2550	3010	3445	4105	
		COP	2.30	2.30	2.30	2.30	2.30	2.40	
	<sup>2</sup> Sound	d Rating Number (dBA)	78	78	76	78	79	78	
Refrigerant		Туре	R-410A	R-410A	R-410A	R-410A	R-410A	R-410A	
		Charge	5 lbs. 11 oz.	6 lbs. 0 oz.	5 lbs. 12 oz.	10 lbs. 5 oz.	10 lbs. 3 oz.	10 lbs. 1 oz	
Condensate d	rain size (fpt)	- in.	3/4	3/4	3/4	3/4	3/4	3/4	
Outdoor Coil		Net Face Area - sq. ft.	16.4	16.4	16.4	16.6	16.6	18.6	
		Tube diameter - in.	5/16	5/16	5/16	5/16	5/16	5/16	
		Number of Rows	1	1	1	2	2	2	
		Fins per in.	22	22	22	22	22	22	
Outdoor Coil		Motor horsepower	1/6	1/6	1/6	1/4	1/4	1/3	
Fan		Diameter - in.	22	22	22	24	24	24	
		Number of blades	4	4	4	3	3	3	
Indoor Coil		Net Face Area - sq. ft.	4.4	4.4	4.4	6.8	6.8	6.8	
		Tube Diameter - in.	5/16	3/8	3/8	3/8	3/8	3/8	
		Number of Rows	3	3	3	3	3	3	
		Fins per Inch	15	15	15	15	15	15	
Indoor Blower	Blower whe	eel size dia. x width - in.	10 x 6	10 x 6	10 x 8	10 x 10	10 x 10	12 x 10	
Motor horsepower			1/3	1/2	1/2	3/4	3/4	1	
Net weight of I	basic unit - Ib	s.	383	392	402	505	510	532	
Shipping weig	ht of basic ur	nit (1 Pkg.) - Ibs.	388	397	407	510	515	537	
Electrical char	acteristics (6	0 Hz)	208/230V-1ph-60Hz						

<sup>1</sup>AHRI Certified to AHRI Standard 210/240:

Cooling Ratings - 95°F outdoor air temperature and 80°F db/67°F wb entering indoor coil air.

High Temperature Heating Ratings - 47°F db/43°F wb outdoor air temperature and 70°F entering indoor coil air. Low Temperature Heating Ratings - 17°F db/15°F wb outdoor air temperature and 70°F entering indoor coil air.

<sup>2</sup> Sound Rating Number rated in accordance with test conditions included in AHRI Standard 270.

Specificat	ions – LRP14AC						
General Data	Model No.	LRP14AC24	LRP14AC30	LRP14AC36	LRP14AC42	LRP14AC48	LRP14AC60
	Nominal Tonnage	2	2.5	3	3.5	4	5
Cooling	Total cooling capacity - Btuh	22,600	28,400	34,000	40,000	45,500	57,000
Performance	Total unit watts	2055	2580	3090	3635	4180	5180
	<sup>1</sup> SEER (Btuh/Watt)	14.00	14.00	14.00	14.00	14.00	14.00
	EER (Btuh/Watt)	11.00	11.00	11.00	11.00	11.00	11.00
	<sup>2</sup> Sound Rating Number (dBA)	77	79	78	78	77	78
Refrigerant	Туре	R-410A	R-410A	R-410A	R-410A	R-410A	R-410A
	Charge	4 lbs. 8 oz.	5 lbs. 0 oz.	5 lbs. 7 oz.	6 lbs. 12 oz.	7 lbs. 3 oz.	7 lbs. 13 oz.
Condensate d	rain size (fpt) - in.	3/4	3/4	3/4	3/4	3/4	3/4
Outdoor Coil	Motor horsepower	1/6	1/6	1/6	1/4	1/4	1/4
Fan	Diameter - in. & No. of blades	22 - 4	22 - 4	22 - 4	24 - 3	24 - 3	24 - 3
Indoor	Blower wheel size dia. x width - in.	10 x 6	10 x 6	10 x 8	10 x 10	10 x 10	12 x 9
Blower	Motor horsepower	1/3	1/2	1/2	3/4	3/4	1
Net weight of	basic unit - Ibs.	381	393	401	474	478	517
Shipping weig	ht of basic unit (1 Pkg.) - Ibs.	386	398	406	479	483	522
Electrical cha	racteristics (60 Hz)			208/230V-	-1ph-60Hz		

<sup>1</sup> AHRI Certified to AHRI Standard 210/240; 95°F outdoor air temperature, 80°F db/67°F wb entering evaporator air.

<sup>2</sup> Sound Rating Number rated in accordance with test conditions included in AHRI Standard 270.

## Specifications – LRP14GE / LRP14GX

General Data	Model No.	LRP14GE24	LRP14GE30	LRP14GE36	LRP14GE42	LRP14GE48	LRP14GE60
	Model No Low NOX	LRP14GX24	LRP14GX30	LRP14GX36	LRP14GX42	LRP14GX48	LRP14GX60
	Nominal Tonnage	2	2.5	3	3.5	4	5
Gas Heat Availa	ble - See Page Page 9	-054(GX), -072	-054(GX), -072	054, -072(GX), -090	-072(GX), -090	-108(GX), -126	-108(GX), -126
Cooling	Total cooling capacity - Btuh	22,600	28,400	34,000	40,000	45,500	57,000
Performance	Total Unit Watts	2055	2580	3090	3635	4180	5180
	<sup>1</sup> SEER (Btuh/Watt)	14.00	14.00	14.00	14.00	14.00	14.00
	EER (Btuh/Watt)	11.00	11.00	11.00	11.00	11.00	11.00
	<sup>2</sup> Sound Rating Number (dBA)	77	79	78	78	77	78
Refrigerant	Туре	R-410A	R-410A	R-410A	R-410A	R-410A	R-410A
	Charge	4 lbs. 8 oz.	5 lbs. 0 oz.	5 lbs. 7 oz.	6 lbs. 12 oz.	7 lbs. 3 oz.	7 lbs. 13 oz.
Condensate dra	ain size (fpt) - in.	3/4	3/4	3/4	3/4	3/4	3/4
Outdoor Coil	Net Face Area - sq. ft.	14.6	16.4	16.4	19.5	19.5	16.6
	Tube Dia in. and No. of Rows	5/16 - 1	5/16 - 1	5/16 - 1	5/16 - 1	5/16 - 1	5/16 - 2
	Fins per inch	26	26	26	26	26	22
Outdoor Coil	Motor horsepower	1/6	1/6	1/6	1/4	1/4	1/4
Fan	Dia in. and No. of blades	22 - 4	22 - 4	22 - 4	24 - 3	24 - 3	24 - 3
Indoor Coil	Net Face Area - sq. ft.	4.4	4.4	4.4	6.8	6.8	6.8
	Tube Dia in. and No. of rows	3/8 - 2	5/16 - 3	5/16 - 3	5/16 - 3	5/16 - 3	3/8 - 3
	Fins per in.	16	16	15	15	15	15
Indoor Blower	Blower wheel size dia. x width - in.	10 x 6	10 x 6	10 x 8	10 x 10	10 x 10	12 x 9
	Motor horsepower	1/3	1/2	1/2	3/4	3/4	1
Net weight of ba	asic unit - Ibs.	405	417	433	507	523	560
Shipping weigh	t of basic unit (1 Pkg.) - lbs.	410	422	438	512	528	565
Electrical chara	cteristics (60 Hz)			208/230V-	1ph-60Hz		

General Data	Model No.	LRP14GN24	LRP14GN30	LRP14GN36	LRP14GN42	LRP14GN48	LRP14GN6
	Nominal Tonnage	2	2.5	3	3.5	4	5
Gas Heat Availa	able - See Page Page 9	-054	-054	-054	-072	-072	-072
Cooling	Total cooling capacity - Btuh	22,600	28,400	34,000	40,000	45,500	57,000
Performance	Total Unit Watts	2055	2580	3090	3635	4180	5180
	<sup>1</sup> SEER (Btuh/Watt)	14.00	14.00	14.00	14.00	14.00	14.00
	EER (Btuh/Watt)	11.00	11.00	11.00	11.00	11.00	11.00
	<sup>2</sup> Sound Rating Number (dBA)	77	79	78	78	77	78
Refrigerant	Туре	R-410A	R-410A	R-410A	R-410A	R-410A	R-410A
	Charge	4 lbs. 8 oz.	5 lbs. 0 oz.	5 lbs. 7 oz.	6 lbs. 12 oz.	7 lbs. 3 oz.	8 lbs. 11 oz.
Condensate dra	ain size (fpt) - in.	3/4	3/4	3/4	3/4	3/4	3/4
Outdoor Coil	Net Face Area - sq. ft.	14.6	16.4	16.4	19.5	19.5	16.6
	Tube Dia in. and No. of Rows	5/16 - 1	5/16 - 1	5/16 - 1	5/16 - 1	5/16 - 1	5/16 - 2
	Fins per inch	26	26	26	26	26	22
Outdoor Coil	Motor horsepower	1/6	1/6	1/6	1/4	1/4	1/4
Fan	Dia in. and No. of blades	22 - 4	22 - 4	22 - 4	24 - 3	24 - 3	24 - 3
Indoor Coil	Net Face Area - sq. ft.	4.4	4.4	4.4	6.8	6.8	6.8
	Tube Dia in. and No. of rows	3/8 - 2	5/16 - 3	5/16 - 3	5/16 - 3	5/16 - 3	3/8 - 3
	Fins per in.	16	16	15	15	15	15
Indoor Blower	Blower wheel size dia. x width - in.	10 x 6	10 x 6	10 x 8	10 x 10	10 x 10	12 x 10
	Motor horsepower	1/3	1/2	1/2	3/4	3/4	1
Net weight of b	asic unit - Ibs.	401	408	424	516	519	551
Shipping weigh	nt of basic unit (1 Pkg.) - Ibs.	407	414	430	522	525	557
Electrical chara	actoristics (60 Hz)			208/230\/_	1ph_60Hz		

## Specifications – LRP14GN

Electrical characteristics (60 Hz)

208/230V-1ph-60Hz

				I	
General Data	Model No.	LRP16GE24	LRP16GE36	LRP16GE48	LRP16GE60
	Model No Low NOX	LRP16GX24	LRP16GX36	LRP16GX48	LRP16GX60
	Nominal Tonnage	2	3	4	5
Gas Heat Available	- See Page 9	-72	-72, -90	-108	-126
Cooling	Total cooling capacity - Btuh	23,800	35,400	47,500	57,000
Performance	Total Unit Watts	1900	2950	3960	4750
	<sup>1</sup> SEER (Btuh/Watt)	16.0	16.0	16.0	16.0
	EER (Btuh/Watt)	12.5	12.0	12.0	12.0
	<sup>2</sup> Sound Rating Number (dBA)	74	75	75	74
Refrigerant	Туре	R-410A	R-410A	R-410A	R-410A
	Charge	5 lbs. 7 oz.	5 lbs. 12 oz.	6 lbs. 10 oz.	9 lbs. 1 oz.
Condensate drain	size (fpt) - in.	3/4	3/4	3/4	3/4
Outdoor Coil	Net Face Area - sq. ft.	14.6	16.4	19.5	19.1
	Tube Dia in. and No. of Rows	5/16 – 1	5/16 – 1	5/16 – 1	5/16 – 2
	Fins per inch	26	26	26	22
Outdoor Coil	Motor horsepower	1/6	1/6	1/4	1/4
Fan	Dia in. and No. of blades	22 – 3	22 – 3	24 – 3	24 – 3
ndoor Coil	Net Face Area - sq. ft.	4.4	4.4	6.8	6.8
	Tube Dia in. and No. of rows	3/8 – 3	3/8 – 3	3/8 – 3	3/8 – 3
	Fins per in.	15	15	15	15
Indoor Blower	Blower wheel size dia. x width - in.	10 x 6	10 x 8	10 x 10	12 x 9
	Motor horsepower	1/2	1/2	3/4	1
Net weight of basic	c unit - Ibs.	425	437	536	572
Shipping weight of	f basic unit (1 Pkg.) - Ibs.	430	442	541	577
Electrical characte	ristics (60 hz)		208/230V	-1ph-60Hz	

General Data		Model No.	LRP16HP24	LRP16HP36	LRP16HP48	LRP16HP60
		Nominal Tonnage	2	3	4	5
Cooling /	Cooling	Total capacity - Btuh	23,000	35,000	47,000	57,000
leating Performance		Total unit watts	1910	2910	3910	4950
		<sup>1</sup> SEER (Btuh/Watt)	16.0	16.0	16.0	15.5
		EER (Btuh/Watt)	12.0	12.0	12.0	11.5
	High Temp.	Total capacity - Btuh	22,000	34,000	46,000	56,000
	Heat	Total unit watts	1791	2770	3740	4440
		COP	3.60	3.60	3.60	3.70
		HSPF (Region IV)	8.20	8.20	8.20	8.20
	Low Temp.	Total capacity - Btuh	11,900	19,700	26,600	37,200
	Heat	Total unit watts	1480	2530	3500	4250
		COP	2.36	2.28	2.23	2.57
	<sup>2</sup> Soun	d Rating Number (dBA)	71	71	74	74
Refrigerant		Туре	R-410A	R-410A	R-410A	R-410A
		Charge	5 lbs. 5 oz.	8 lbs. 0 oz.	10 lbs. 8 oz.	10 lbs. 8 oz
condensate di	ain size (fpt)	- in.	3/4	3/4	3/4	3/4
Outdoor Coil		Net Face Area - sq. ft.	16.3	15.5	18.6	18.6
		Tube diameter - in.	5/16	5/16	5/16	5/16
		Number of Rows	1	2	2	2
		Fins per in.	22	22	22	22
outdoor Coil		Motor horsepower	1/2	1/2	1/2	1/2
an		Diameter - in.	22	22	24	24
		Number of blades	3	3	3	3
ndoor Coil		Net Face Area - sq. ft.	4.4	4.4	6.8	6.8
		Tube Diameter - in.	5/16	3/8	3/8	3/8
		Number of Rows	3	3	3	3
		Fins per Inch	15	15	15	15
ndoor Blower	Blower whe	eel size dia. x width - in.	10 x 6	10 x 8	10 x 10	12 x 9
		Motor horsepower	1/2	1/2	3/4	1
let weight of <b>k</b>	basic unit - Ib	os.	425	460	540	555
Shipping weight of basic unit (1 Pkg.) - Ibs.			430	465	545	560
ectrical char	acteristics (6	60 hz)		208/230V	-1ph-60hz	

<sup>1</sup>AHRI Certified to AHRI Standard 210/240: **Cooling Ratings** - 95°F outdoor air temperature and 80°F db/67°F wb entering indoor coil air. **High Temperature Heating Ratings** - 47°F db/43°F wb outdoor air temperature and 70°F entering indoor coil air. **Low Temperature Heating Ratings** - 17°F db/15°F wb outdoor air temperature and 70°F entering indoor coil air.

<sup>2</sup> Sound Rating Number rated in accordance with test conditions included in AHRI Standard 270.

## Electric Heat Capacities – LRP14HP and AC Models – LRP16HP

<b>1</b>	5 kW		7.5 kW				10 kW		15 kW			20 kW			
Input Voltage	No of Steps	kW input	Btuh Output												
208	1	3.8	12,800	1	5.6	19,200	1	7.5	25,600	1	11.2	38,200	1	15.0	51,200
220	1	4.2	14,300	1	6.3	21,500	1	8.4	28,700	1	12.6	43,000	1	16.8	57,300
230	1	4.6	15,700	1	6.9	23,500	1	9.2	31,300	1	13.8	47,000	1	18.4	62,700
240	1	5.0	17,100	1	7.5	25,600	1	10.0	34,100	1	15.0	51,200	1	20.0	68,200

## Gas Heat Capacities – LRP14GE Only

	Model	24, 30, 36	24, 30	36, 42	36, 42	48, 60	48, 60		
	Heating Input	-054	-072	-072	-090	-108	-126		
Heating	Input	54,000	72,000	72,000	90,000	108,000	126,000		
Capacity Btuh	Output	43,800	58,400	58,400	72,900	87,500	102,100		
<sup>1</sup> AFUE		81%	81%	81%	81%	81%	81%		
Temperature Rise - °F		30-60	40-70	35-65	40-70	40-70	45-75		
Gas Supply Connection (FPT) - in.		1/2	1/2	1/2	1/2	1/2	1/2		
Min. Recommended Gas	s Supply Pressure	5 in. w.g. Natural Gas, 11 in. w.g LPG / Propane							

<sup>1</sup> Annual Fuel Utilization Efficiency based on U.S. DOE test procedures and FTC labeling regulations.

## Gas Heat Capacities – LRP16GE Only

	Model	24, 36	36	48	60			
	Heating Input	-072	-090	-108	-126			
Heating	First Stage - Input	54,000	67,500	81,000	94,500			
Capacity Btuh	Output	43,500	54,500	65,500	76,500			
	Second Stage Input	72,000	90,000	108,000	126,000			
	Output	58,000	73,000	88,000	102,000			
<sup>1</sup> AFUE		81%	81%	81%	81%			
Temperature Rise -	°F First Stage	35-45	35-45	45-55	45-55			
	Second Stage	45-55	45-55	50-60	50-60			
Gas Supply Conne	ction (FPT) - in.	1/2	1/2	1/2	1/2			
Vin. Recommended	Gas Supply Pressure	5 in. w.g. Natural Gas, 11 in. w.g LPG / Propane						

<sup>1</sup> Annual Fuel Utilization Efficiency based on U.S. DOE test procedures and FTC labeling regulations.

## Gas Heat Capacities – LRP14GN Only

	Model	24, 30, 36	42, 48, 60			
	Heating Input	-054	-072			
Heating Capacity	Input	54,000	72,000			
Btuh	Output	43,800	58,320			
<sup>1</sup> AFUE		81%	81%			
Temperature Rise - °F		30 - 60	25 - 55			
Gas Supply Connectior	ı (FPT) - in.	1/2	1/2			
Min. Recommended Ga	s Supply Pressure	5 in. w.g. Natural Gas, 11 in. w.g. LPG/Propane				

<sup>1</sup> Annual Fuel Utilization Efficiency based on U.S. DOE test procedures and FTC labeling regulations.

ELECTRIC HEA	T DATA — LRF	P14HP On	ly					
	N	lodel No.	LRP1	4HP24	LRP1	4HP30	LRP1	4HP36
Line vol	tage data - 60hz	- 1 phase	208/	/230V	208/	230V	208/	/230V
Compressor	Rated L	oad Amps	1	0.9	13.5		15.4	
	Locked R	otor Amps	59.3		72	2.5	83.9	
Outdoor Fan	Full L	Full Load Amps		.0	1	.0	1	.0
Motor	Locked R	otor Amps	1	.9	1	.9	1	.9
Indoor	Full L	oad Amps	2	2.8	2	.8	4	l.1
Blower Motor	Locked R	otor Amps	3	3.9	3	.9	4	1.4
<sup>1</sup> Maximum		Voltage	208V	240V	208V	240V	208V	240V
Overcurrent — Protection —	Unit only, no el	ectric heat	25	25	30	30	35	35
		5 kW	30	30	30	30	30	35
		7.5 kW	40	45	40	45	40	45
		10 kW	50	60	50	60	50	60
	<sup>3</sup> 15 kW	Circuit 1			50	60	50	60
		Circuit 2			25	30	25	30
<sup>1</sup> Maximum Overcur		5 kW	45	45	45	50	50	50
Protection with Opti Single-Point Power	ional	7.5 kW	60	60	60	60	60	70
Supply		10 kW	70	70	70	80	70	80
		15 kW			90	100	100	110
<sup>2</sup> Minimum	Unit only, no el	ectric heat	17.4	17.4	20.7	20.7	24.4	24.4
Circuit — Ampacity		5 kW	25.4	28.8	25.4	28.8	26.7	30.1
Ampuony		7.5 kW	36.7	41.9	36.7	41.9	38	43.2
		10 kW	47.9	54.9	47.9	54.9	49.2	56.2
	<sup>3</sup> 15 kW	Circuit 1			47.9	54.9	49.2	56.2
		Circuit 2			22.6	26	22.6	26
<sup>2</sup> Minimum Circuit		5 kW	39.1	42.4	42.3	45.7	46	49.4
Ampacity with Optic Single-Point Power	onal	7.5 kW	50.3	55.6	53.6	58.8	57.2	62.5
Supply		10 kW	61.6	68.6	64.8	71.8	68.5	75.5
		15 kW			87.4	97.8	91.1	101.5

 NOTE - All units have a minimum Short Circuit Current Rating (SCCR) of 5000 amps.

 NOTE - Circuit 1 Minimum Circuit Ampacity includes the Blower Motor Full Load Amps.

 NOTE - Extremes of operating range are plus and minus 10% of line voltage.

 1
 HACR type breaker or fuse.

 2
 Refer to National or Canadian Electrical Code manual to determine wire, fuse and disconnect size requirements.

 3
 A separate compressor circuit is required.

ELECTRIC HE	at data — Lri	P14HP Or	nly (Contd.)					
	N	lodel No.	LRP1	4HP42	LRP1	4HP48	LRP14	4HP60
Line v	oltage data - 60hz	- 1 phase	208	/230V	208/	230V	208/2	230V
Compressor	Rated L	oad Amps	1	5.9	1	18	24	.3
	Locked R	otor Amps	:	35	1	17	14	4.2
Outdoor Fan	Full L	oad Amps		1.7	1	.7	1.	.7
Motor	Locked R	otor Amps	3	3.2	3	.2	3	2
Indoor	Full L	oad Amps	2	2.8	2	8	7.6	
Blower Motor	Locked R	otor Amps	ţ	5.4	6	.8		
<sup>1</sup> Maximum		Voltage	208V	240V	208V	240V	208V	240V
Overcurrent - Protection _	Unit only, no el	Unit only, no electric heat		40	45	45	60	60
		5 kW	30	30	30	30	35	35
		7.5 kW	40	45	40	45	45	50
		10 kW	50	60	50	60	60	60
	<sup>3</sup> 15 kW	Circuit 1	50	60	50	60	60	60
		Circuit 2	25	30	25	30	25	30
	<sup>3</sup> 20 kW	Circuit 1	50	60	50	60	50	60
		Circuit 2	50	60	50	60	50	60
<sup>1</sup> Maximum Overc		5 kW	50	50	60	60	80	80
Protection with O Single-Point Pow		7.5 kW	60	70	70	70	80	90
Supply		10 kW	70	80	80	80	90	100
		15 kW	100	110	100	110	110	125
		20 kW	125	150	125	150	150	150
<sup>2</sup> Minimum	Unit only, no el	ectric heat	24.4	24.4	27	27	39.7	39.7
Circuit – Ampacity		5 kW	25.4	28.8	25.4	28.8	30.2	33.6
		7.5 kW	36.7	41.9	36.7	41.9	41.5	46.7
		10 kW	47.9	54.9	47.9	54.9	52.7	59.7
	<sup>3</sup> 15 kW	Circuit 1	47.9	54.9	47.9	54.9	52.7	59.7
		Circuit 2	22.6	26	22.6	26	22.6	26
	<sup>3</sup> 20 kW	Circuit 1	47.9	54.9	47.9	54.9	52.7	59.7
		Circuit 2	45.1	52.1	45.1	52.1	45.1	52.1
<sup>2</sup> Minimum Circui		5 kW	45.3	48.7	47.9	51.3	60.6	64
Ampacity with Op Single-Point Pow		7.5 kW	56.6	61.8	59.2	64.4	71.9	77.1
Supply		10 kW	67.8	74.8	70.4	77.4	83.1	90.1
		15 kW	90.4	100.8	93.1	103.4	105.7	116.1
		20 kW	112.9	126.8	115.6	129.4	128.2	142.1

#### ELECTRIC HEAT DATA — LRP14HP Only (Contd.)

 NOTE - All units have a minimum Short Circuit Current Rating (SCCR) of 5000 amps.

 NOTE - Circuit 1 Minimum Circuit Ampacity includes the Blower Motor Full Load Amps.

 NOTE - Extremes of operating range are plus and minus 10% of line voltage.

 1

 HACR type breaker or fuse.

 2

 Refer to National or Canadian Electrical Code manual to determine wire, fuse and disconnect size requirements.

 3

 3

 A separate compressor circuit is required.

## **ELECTRIC HEAT DATA — LRP14AC Only**

	M	odel No.	LRP1	4AC24	LRP1	4AC30	LRP14	4AC36
Line volta	ige data - 60Hz	- 1 phase	208/	230V	208/	230V	208/	230V
Compressor	Rated Lo	oad Amps	1	0.9	13.5		15	5.4
	Locked Ro	Locked Rotor Amps		9.3	72.5		83.9	
Outdoor Fan	Full Lo	oad Amps	1	.0	1	.0	1	.0
Motor	Locked Ro	otor Amps	1	.9	1	.9	1	.9
Indoor	Rated Lo	oad Amps	2	2.8	2	.8	4	.1
Blower Motor	Locked Ro	otor Amps	3	8.9	3	.9	4	.4
<sup>1</sup> Maximum		Voltage	208V	240V	208V	240V	208V	240V
Overcurrent Protection	Unit only, no ele	ectric heat	25	25	30	30	30	30
		5 kW	25	30	25	30	25	30
		7.5 kW	40	45	40	45	40	45
		10 kW	50	60	50	60	50	60
	<sup>3</sup> 15 kW	Circuit 1			50	60	50	60
		Circuit 2			25	30	25	30
<sup>1</sup> Maximum Overcurr		5 kW	25	30	30	30	30	30
Protection with Optic Single-Point Power	onal	7.5 kW	40	45	40	45	40	45
Supply		10 kW	50	60	50	60	50	60
		15 kW			70	80	70	90
<sup>2</sup> Minimum	Unit only, no ele	ectric heat	16.7	16.7	18.7	18.7	20.6	20.6
Circuit Ampacity		5 kW	24.3	27.7	24.3	27.7	24.6	28
linpuolty		7.5 kW	35.6	40.8	35.6	40.8	35.9	41.1
		10 kW	46.8	53.8	46.8	53.8	47.1	54.1
	<sup>3</sup> 15 kW	Circuit 1			46.8	53.8	47.1	54.1
		Circuit 2			22.6	26	22.6	26
<sup>2</sup> Minimum Circuit		5 kW	24.3	27.7	24.3	27.7	24.6	28
Ampacity with Option Single-Point Power	nal	7.5 kW	35.6	40.8	35.6	40.8	35.9	41.1
Supply		10 kW	46.8	53.8	46.8	53.8	47.1	54.1
		15 kW			69.4	79.8	69.7	80.1

 NOTE - All units have a minimum Short Circuit Current Rating (SCCR) of 5000 amps.

 NOTE - Circuit 1 Minimum Circuit Ampacity includes the Blower Motor Full Load Amps.

 NOTE - Extremes of operating range are plus and minus 10% of line voltage.

 1
 HACR type breaker or fuse.

 2
 Refer to National or Canadian Electrical Code manual to determine wire, fuse and disconnect size requirements.

 3
 A separate compressor circuit is required.

	N	lodel No.	LRP1	4AC42	LRP1	4AC48	LRP14	4AC60
Line voltag	je data - 60Hz	- 1 phase	208/	230V	208/	230V	208/2	230V
Compressor		oad Amps	1:	5.9	-	18	24	4.3
	Locked R	otor Amps	8	35	1	17	14	4.2
Outdoor Fan	Full L	oad Amps	1	.7	1	.7	1	.7
Motor	Locked R	otor Amps	3	3.2	3	3.2	3	.2
Indoor	Rated L	oad Amps	2	2.8	2	2.8	7	.6
Blower Motor	Locked R	otor Amps	5	5.4	6	6.8		
<sup>1</sup> Maximum		Voltage	208V	240V	208V	240V	208V	240V
Overcurrent Protection	Unit only, no el	ectric heat	40	40	40	40	60	60
		5 kW	30	30	30	30	35	35
		7.5 kW	40	45	40	45	45	50
		10 kW	50	60	50	60	60	60
	<sup>3</sup> 15 kW	Circuit 1	50	60	50	60	60	60
		Circuit 2	25	30	25	30	60	60
	<sup>3</sup> 20 kW	Circuit 1	50	60	50	60	60	60
		Circuit 2	50	60	50	60	60	60
<sup>1</sup> Maximum Overcurre		5 kW	40	40	40	40	60	60
Protection with Optior Single-Point Power	nal	7.5 kW	40	45	40	45	60	60
Supply		10 kW	50	60	50	60	60	60
		15 kW	80	90	80	90	80	90
	-	20 kW	100	110	100	110	100	125
<sup>2</sup> Minimum	Unit only, no el		24.4	24.4	26.9	26.9	38.9	38.9
Circuit ——— Ampacity		5 kW	25.4	28.8	25.4	28.8	30.2	33.6
100 C		7.5 kW	36.7	41.9	36.7	41.9	41.5	46.7
		10 kW	47.9	54.9	47.9	54.9	52.7	59.7
	<sup>3</sup> 15 kW	Circuit 1	47.9	54.9	47.9	54.9	52.7	59.7
	. <u> </u>	Circuit 2	22.6	26	22.6	26	22.6	26
	<sup>3</sup> 20 kW	Circuit 1	47.9	54.9	47.9	54.9	52.7	59.7
		Circuit 2	45.1	52.1	45.1	52.1	45.1	52.1
<sup>2</sup> Minimum Circuit	-l	5 kW	25.4	28.8	26.9	28.8	38.9	38.9
Ampacity with Optiona Single-Point Power	ai	7.5 kW	36.7	41.9	36.7	41.9	41.5	46.7
Supply		10 kW	47.9	54.9	47.9	54.9	52.7	59.7
		15 kW	70.5	80.9	70.5	80.9	75.3	85.7
		20 kW	93	107	93	107	97.8	111.8

### ELECTRIC HEAT DATA — LRP14AC Only (Contd.)

NOTE - All units have a minimum Short Circuit Current Rating (SCCR) of 5000 amps.

NOTE - Circuit 1 Minimum Circuit Ampacity includes the Blower Motor Full Load Amps.

NOTE - Extremes of operating range are plus and minus 10% of line voltage. 1

HACR type breaker or fuse.

<sup>2</sup> Refer to National or Canadian Electrical Code manual to determine wire, fuse and disconnect size requirements.

<sup>3</sup> A separate compressor circuit is required.

## ELECTRICAL DATA — LRP14GE Only

	Model No.	LRP14GE24	LRP14GE30	LRP14GE36	LRP14GE42	LRP14GE48	LRP14GE60
Line	Line voltage data - 60hz - 1 phase		208/230V		208/230V		230V
<sup>1</sup> Maximum Ove	ercurrent Protection (amps)	25	30	30	40	40	60
<sup>2</sup> Minimum Circ	cuit Ampacity	16.7	18.7	20.6	24.4	26.9	38.9
Compressor	Rated Load Amps	11.2	12.8	14.1	15.9	17.9	23.7
	Locked Rotor Amps	60.8	64	72.2	85	96	152.5
Outdoor Coil	Full Load Amps	1.0	1.0	1.0	1.7	1.7	1.7
Fan Motor	Locked Rotor Amps	1.9	1.9	1.9	3.2	3.2	3.2
Indoor	Full Load Amps	1.7	1.7	2.0	2.8	2.8	7.6
Blower Motor	Locked Rotor Amps	3.9	3.9	4.4	5.4	6.8	

 NOTE - All units have a minimum Short Circuit Current Rating (SCCR) of 5000 amps.

 NOTE - Extremes of operating range are plus and minus 10% of line voltage.

 1
 HACR type breaker or fuse.

 2
 Refer to National or Canadian Electrical Code manual to determine wire, fuse and disconnect size requirements.

## **ELECTRICAL DATA – LRP14GN**

	Model No.	LRP14GN24	LRP14GN30	LRP14GN36	LRP14GN42	LRP14GN48	LRP14GN60
Line voltage data - 60	Hz 1 phase	208/230V	208/230V	208/230V	208/230V	208/230V	208/230V
<sup>3</sup> Maximum Overcurrent Protection (MOCP) amps		20	25	35	40	40	60
<sup>4</sup> Minimum Circuit Ampacity (MCA)		14.4	18.2	22.7	27.5	28.7	38.9
Compressor	Rated load amps	8.6	10.6	15.7	15.9	16.9	26.4
	Locked rotor amps	63.5	67	72.2	112.3	94	152.5
Outdoor Coil	Full load amps	1.0	1.0	1.0	1.7	1.7	1.7
Fan Motor	Locked rotor amps	1.9	1.9	1.9	3.2	3.2	3.2
Indoor Blower	Full load amps	2.8	4.1	4.1	6	6	7.6
Motor	Locked rotor amps	3.9	3.9	4.4	5.4	6.8	

NOTE-Extremes of operating range are plus and minus 10% of line voltage.

<sup>1</sup> AHRI Certified to AHRI Standard 210/240; 95°F outdoor air temperature, 80°F db/67°F wb entering evaporator air.

<sup>2</sup> Sound Rating Number rated in accordance with test conditions included in AHRI Standard 270.

<sup>3</sup> HACR type circuit breaker or fuse.

<sup>4</sup> Refer to National or Canadian Electrical Code manual to determine wire, fuse and disconnect size requirements.

#### ELECTRICAL DATA — LRP16GE Only

	Model No.	LRP16GE24	LRP16GE36	LRP16GE48	LRP16GE60
	Line voltage data - 60hz - 1 phase		208/2	230V	·
<sup>1</sup> Maximum Overcurren	t Protection (amps)	25	35	50	60
<sup>2</sup> Minimum Circuit Amp	acity	17.0	22.7	31.2	41.7
Compressor	Rated Load Amps	11.7	15.3	21.2	28.8
	Locked Rotor Amps	58.3	83.0	104.0	152.9
Outdoor Coil	Full Load Amps	1.0	1.0	1.7	1.7
Fan Motor	Locked Rotor Amps	1.9	1.9	3.2	3.2
Indoor	Full Load Amps	1.1	2.3	3.1	4.0
Blower Motor	Locked Rotor Amps	4.3	4.3	6.8	9.1

 NOTE - All units have a minimum Short Circuit Current Rating (SCCR) of 5000 amps.

 NOTE - Extremes of operating range are plus and minus 10% of line voltage.

 1
 HACR type breaker or fuse.

 2
 Refer to National or Canadian Electrical Code manual to determine wire, fuse and disconnect size requirements.

### **ELECTRIC HEAT DATA — LRP16HP Only**

		Model No.	LRP1	6HP24	LRP1	6HP36	LRP10	6HP48	LRP10	6HP60
Line volta	age data - 60	nz - 1 phase	208/	230V	208/	230V	208/2	230V	208/	230V
Compressor	Rateo	d Load Amps	11.7		16.1		21.2		27	<b>'</b> .1
	Locked	Rotor Amps	58	3.3	83	3.0	104.0		15	2.9
Outdoor Fan Motor	Fu	I Load Amps	1	.2	1	.4	2	.3	2	.4
Indoor Blower Motor	Full Load Amps		1	.7	3	.6	4.5		5.5	
<sup>1</sup> Maximum		Voltage	208V	240V	208V	240V	208V	240V	208V	240V
Overcurrent Protection	Unit only, no	electric heat	25	25	40	40	50	50	60	60
		5 kW	25	30	30	35	30	35	35	35
	-	7.5 kW	40	45	40	45	40	45	45	50
	-	10 kW	50	60	50	60	60	60	60	60
	<sup>3</sup> 15 kW	Circuit 1			50	60	60	60	60	60
	-	Circuit 2			25	30	25	30	25	30
	<sup>3</sup> 20 kW	Circuit 1					60	60	60	60
		Circuit 2					50	60	50	60
<sup>1</sup> Maximum Overcurrent		5 kW	45	50	50	60	70	70	80	90
Protection with Optional		7.5 kW	60	60	60	70	80	80	90	100
Single-Point Power Supply		10 kW	70	80	80	80	90	90	100	110
		15 kW			100	110	110	125	110	125
		20 kW					125	150	150	150
<sup>2</sup> Minimum	Unit only, no	electric heat	18.0	18.0	25.6	25.6	33.8	33.8	42.3	42.3
Circuit —— Ampacity		5 kW	24.7	28.2	27.1	30.5	28.2	31.7	29.5	32.9
Ampacity		7.5 kW	36.0	41.2	38.3	43.6	39.5	44.7	40.7	45.9
		10 kW	47.3	54.2	49.6	56.6	50.8	57.7	52.0	59.0
	<sup>3</sup> 15 kW	Circuit 1			49.6	56.6	50.8	57.7	52.0	59.0
	-	Circuit 2			22.6	26.0	22.6	26.0	22.6	26.0
	<sup>3</sup> 20 kW	Circuit 1					50.8	57.7	52.0	59.0
		Circuit 2					45.1	52.1	45.1	52.1
<sup>2</sup> Minimum Circuit		5 kW	40.6	44.0	48.2	51.6	56.4	59.8	64.9	68.3
Ampacity with Optional Single-Point Power		7.5 kW	51.8	57.1	59.4	64.7	67.6	72.8	76.1	81.3
Supply		10 kW	63.1	70.1	70.7	77.7	78.9	85.9	87.4	94.3
		15 kW			93.3	103.7	101.5	111.9	110.0	120.4
		20 kW					124.1	137.9	132.5	146.4

NOTE - All units have a minimum Short Circuit Current Rating (SCCR) of 5000 amps.
NOTE - Circuit 1 Minimum Circuit Ampacity includes the Blower Motor Full Load Amps.
NOTE - Extremes of operating range are plus and minus 10% of line voltage.
1 HACR type breaker or fuse.
2 Refer to National or Canadian Electrical Code manual to determine wire, fuse and disconnect size requirements.
3 A separate compressor circuit is required.

#### HIGH ALTITUDE DERATE


Units may be installed at altitudes up to 4500 feet (1372 m) above sea level without any modification. At altitudes above 4500 feet (1372 m), units must be derated as shown in table 1.


NOTE - This is the only permissible derate for these units.


Altitude (ft.)	Heating value* (BTU/ft)		l Pressure w. c.)	Heating value* (BTU/ft)	Manifold Pressure (in. w. c.)		
	(610/19	High	Low	(ВТО/Щ	High	Low	
2000	948	3.50	2.00	2278	10.00	5.60	
3000	914	3.50	2.00	2196	10.00	5.60	
4000	881	3.50	2.00	2116	10.00	5.60	
4500	865	3.50	2.00	2077	10.00	5.60	
5000	849	3.29	1.88	2039	9.41	5.38	
5500	833	3.27	1.87	2000	9.35	5.34	
6000	818	3.25	1.86	1964	9.29	5.31	
6500	802	3.23	1.84	1927	9.24	5.28	
7000	787	3.21	1.83	1891	9.18	5.25	
7500	771	3.19	1.82	1853	9.12	5.21	

#### **TABLE 1. Manifold Pressure Versus Altitude**

## **Typical Parts Arrangement**








**FIGURE 2. Typical Control Box** 

## Parts Arrangement – Contd.



## **Unit Applications**

### LRP14HP

LRP14HP, 2 through 5 ton (7.0 through 17.6kW) model units, are single phase packaged heat pump units designed for outdoor installation on a slab or rooftop in residential applications. The units are available in two cabinet sizes. Optional electric heat must be field installed if required. Units are available with constant torque or PSC blower motors (units manufactured prior to 7/2019 equipped with PSC motors). In heating mode, the unit operates the heat pump for 1st stage heating. If 1st stage is not satisfied, the 2nd stage activates electric heat sections (secondary heat source). Refer to Product Specifications (EHB) for auxiliary heat selections. All heat pump units are equipped with single-stage cooling only.

#### LRP14AC

LRP14AC, 2 through 5 ton (7.0 through 17.6kW) model units, are single phase packaged air conditioning units designed for outdoor installation on a slab or rooftop in residential applications. The units are available in two cabinet sizes. Optional electric heat must be field installed if required. Refer to Product Specifications (EHB) for electric heat options. Units are available with constant torque or PSC blower motors (units manufactured prior to 7/2019 equipped with PSC motors). All LRP14AC units are equipped with single-stage cooling only.

#### LRP14GE

LRP14GE, 2 through 5 ton (7.0 through 17.6kW) model units, are single phase packaged air conditioning units designed for outdoor installation on a slab or rooftop in residential applications. The units are available in two cabinet sizes. A gas heat component is factory installed. Units are available with constant torque or PSC blower motors (units manufactured prior to 7/2019 equipped with PSC motors). All LRP14GE units are equipped with single-stage cooling and gas heat.

#### LRP14GN

LRP14GN, 2 through 5 ton (7.0 through 17.6kW) model units, are single phase packaged air conditioning units designed for outdoor installation on a slab or rooftop in residential applications. The units are available in two cabinet sizes. A gas heat component is factory installed. Units are available with constant torque or PSC blower motors (units manufactured prior to 7/2019 equipped with PSC motors). All LRP14GN units are equipped with single-stage cooling and gas heat.

#### LRP16HP

LRP16HP, 2 through 5 ton (7.0 through 17.6kW) model units, are single phase packaged heat pump units designed for outdoor installation on a slab or rooftop in residential applications. The units are available in two cabinet sizes. Optional electric heat must be field installed if required. Units are equipped with variable-speed ECM blower motors. All LRP16HP units are equipped with a twostage Copeland compressor providing two-stage cooling. In heating mode, the unit operates the heat pump for 1st stage heating. If 1st stage is not satisfied, the 2nd stage activates electric heat sections (secondary heat source). Refer to Product Specifications (EHB) for auxiliary heat selections.

#### LRP16GE

LRP16GE, 2 through 5 ton (7.0 through 17.6kW) model units, are single phase packaged air conditioning units designed for outdoor installation on a slab or rooftop in residential applications. The units are available in two cabinet sizes. A gas heat component is factory installed. Units are equipped with variable-speed ECM blower motors. All LRP16GE units are equipped with a two-stage Copeland compressor providing two-stage cooling and gas heat.

#### **UNIT COMPONENTS / OPERATION**

Unit components are shown in figure 1.

#### **Control Box Components**

Control box components are shown in figure 2.


#### **Compressor Contactor K1**

K1 is a 24VAC to line voltage single-pole contactor, which energizes the compressor and condenser fan in response to thermostat demand.

#### **Control Transformer T1**

All LRP14 series units use line voltage to 24VAC transformer mounted in the control box. The transformer supplies power to control circuits in the unit. Transformers use two primary voltage taps as shown in figure 7.

NOTE - The unit is factory-shipped at 230/240 volts.





#### Dual Capacitor C12

The compressor and condenser fan in the LRP14/16 series units use permanent split capacitor motors. The capacitor is located in the control box. A dual rated capacitor is used for both the condenser fan motor and the compressor (see unit wiring diagram per respective unit). The fan side and the compressor side of the capacitor have different MFD ratings. See repair parts or nameplate for correct capacitor.

#### Ignition Control (A3)

## A WARNING

#### Shock hazard.

Disconnect power before servicing. Control is not field repairable. If control is inoperable, simply replace entire control.

Can cause injury or death. Unsafe operation will result if repair is attempted.

The LRP14GE/LRP14GN and LRP16GE units include an ignition control which controls the combustion air inducer, gas valve and spark electrode. It receives signals from the limit switch, the rollout switch, the pressure prove switch and the flame sensor. The ignition control is shown in figure 9. LED codes are in table 2.

#### **Electronic Ignition**

On a W1 call the ignition control checks high temperature limit and rollout switch to make sure they are closed. The control then verifies that the pressure switch is open. If the pressure switch is closed, the control will flash code 3 on the LED and will wait indefinitely for the pressure switch to open. If the pressure switch is open, the control proceeds to the 15-second pre-purge.

The ignition control energizes the combustion air inducer, flashes a code 3 on the LED, and waits for the pressure switch to close.

When the pressure switch has closed, the LED code 3 flash stops and the control begins the 15-second prepurge period. When the pre-purge time has expired, the control begins the ignition trial.

The ignition control energizes the gas valve and spark. The control ignores the flame sense signal for the first two seconds of the ignition trial. If the flame is established within 10 seconds, the control de-energizes the spark. If flame is not established within 10 seconds, the gas valve and spark are de-energized and the ignition control initiates a 30-second inter-purge sequence. Approximately 30 seconds after the flame has been established, the circulating air blower starts. The ignition control inputs are continuously monitored to ensure that the limit switch, rollout switch and pressure switch are all closed, and that the flame remains established and heating demand is present.

Single-stage gas valve, single-speed combustion air inducer and circulating blower remain energized. If the thermostat signals a requirement for second-stage heat (W2) on the dual fuel unit, the ignition control initiates auxiliary or back-up heat operation.


When a signal for second-stage heat is received by the ignition control, the control energizes the gas valves on dual fuel units and single-speed combustion air inducer until the demand is satisfied.

If a first-stage heat demand continues after the second-stage heat demand has been satisfied, the ignition control immediately de-energizes the gas valve. Heat pump operation continues until heating demand is satisfied.

When the heating demand is satisfied for dual fuel first stage, the control immediately de-energizes the compressor. The combustion air inducer remains energized for a 30-second post-purge period. The circulating air blower operates for 90 seconds after the gas valve is de-energized (GE/GN units only).

The combustion air inducer is energized for 30 seconds at a Y1 call for cooling to clear warm humid air out of the heat exchanger.

The ignition control LED flashes codes which indicate normal or abnormal operations. See table 2.



### FIGURE 8. Ignition Control – Gas-Heat Units Only

#### TABLE 2. LED Diagnostic Codes – Ignition Control

Slow Flash - 1 per second	Normal operation, no call for heat
Fast Flash - 2 per second	Normal operation, call for heat
Steady Off	Internal failure or no power
Steady On	Internal control failure
Code 2 - 2 flashes in 1 sec with 1 sec pause	Lockout, failed to detect or sustain flame, gas valve knob or switch off
<b>Code 3</b> - 3 flashes in 1 1/2 sec with 1 sec pause	Pressure switch open or closed
<b>Code 4</b> - 4 flashes in 2 sec with 1 sec pause	High temp limit or rollout switch open
<b>Code 5</b> - 5 flashes in 2 1/2 sec with 1 sec pause	Flame sensed with gas valve de-energized

## **A WARNING**

Electric Shock Hazard. Can cause injury or death. Unit must be properly grounded in accordance with national and local codes.

Line voltage is present at all components when unit is not in operation on units with single-pole contactors. Disconnect all remote electric power supplies before opening access panel. Unit may have multiple power supplies.




FIGURE 9. Blower Control Board (A54) – ECM Motor – LRP16GE / LRP16HP

#### Blower Control – Units with Constant Torque Motors

LRP14 units that are equipped with constant torque blower motors are energized from the W, G and Y 24 volt terminals from the room thermostat, which are connected to the control board in each unit. The constant torque motor is capable of maintaining a specified CFM throughout the external static range. Constant torque units are not equipped with a separate blower control.

## BLOWER SPEED ADJUSTMENT / OPERATION LRP14 UNITS

#### Blower Speeds – Constant Torque Units

Fan speed on units equipped with constant torque motors is field-adjustable. See blower CFM chart for unit size.

#### Blower Speeds — LRP16GE/HP Units

Fan speed on the HEAT and COOL stage air volume selections are made by jumper pins.

#### **Continuous Fan Operation**

When the thermostat is set for "Continuous Fan" operation and there is no demand for heating or cooling, the blower on units with PSC motors will operate at cooling speed. On units with constant torque motors, the blower will operate at low speed with a G call.

**NOTE** - With the proper thermostat and sub-base, continuous blower operation is possible by closing the R to G circuit. Cooling blower delay is also functional in this mode.

#### Blower Control Board (A54) LRP16GE/HP Units

These units are equipped with a variable-speed motor which is controlled by a blower control board. See figure 11.

On LRP16GE/HP units equipped with ECM motor and a two-stage electronic blower control, the indoor blower is energized by the ignition control.

The variable speed motor that is capable of maintaining a specified CFM throughout the external static range. A particular CFM can be obtained by positioning jumpers (COOL, HEAT, and ADJUST) on the blower control board. The HEAT and COOL jumpers are labeled A, B, C and D. Each of the letters corresponds with an air volume (CFM) setting. The ADJUST jumper is labeled NORM, +, - and Test. The + and - pin settings are used to add or subtract a percentage of the CFM selected. The Test jumper is used to operate the motor in the test mode. See figure 11.

Factory settings for the blower speed jumpers are given in the wiring diagram in figure 11. Use the blower data tables in this manual to determine the correct air volume for operation in heat and cool mode.

The CFM LED located on the blower control board flashes one time per 100 cfm to indicate selected blower speed. For example, if the unit is operating at 1000 CFM, CFM LED will flash 10 times. If the CFM is 1150, CFM LED will flash 11 full times plus one fast or half flash. At times the light may appear to flicker or glow. This takes place when the control is communicating with the motor between cycles. This is normal operation.

Read through the jumper settings section before adjusting the jumper to obtain the appropriate blower speed.

To change jumper positions, gently pull the jumper off the pins and place it on the desired set of pins. The following section outlines the different jumper selections available and conditions associated with each one. Refer to figure 11.

After the CFM for each application has been determined, the jumper settings must be adjusted to reflect those given in the blower tables. From the tables, determine which row most closely matches the desired CFM. Once a specific row has been chosen (+, NORMAL, or -), CFM volumes from other rows cannot be used. Below are descriptions of the jumper selections.

The variable speed motor slowly ramps up to and down from the selected air flow during both cooling and heating demand. This minimizes noise and eliminates the initial blast of air when the blower is initially energized.

#### ADJUST

The **ADJUST** pins allow the motor to run at normal speed, approximately 15 percent higher, or approximately 15 percent lower than normal speed. The blower data tables give three rows (+, NORMAL, and -) with their respective CFM volumes. Notice that the normal adjustment setting for heat speed position C in table 1 is 900 CFM. The + adjustment setting for that position is 1035 CFM and for the - adjustment setting is 765 CFM. After the adjustment setting has been determined, choose the remaining speed settings from those offered in the table in that row.

The TEST pin is available to bypass the blower control and run the motor at approximately 70 percent to make sure that the motor is operational. This is used mainly in troubleshooting. The G terminal must be energized for the motor to run.

### COOL

The **COOL** jumper is used to determine the CFM during cooling operation. This jumper selection is activated for cooling when Y1 is energized. The blower motor runs at 80 percent of the selected air flow for the first 7-1/2 minutes of each cooling demand. This feature allows for greater humidity removal and saves energy. In the cooling mode, the blower control board delays blower operation for 5 seconds after the compressor starts. The blower continues to operate for 90 seconds after the compressor is de-energized.

### HEAT

The **HEAT** jumper is used to determine CFM during gas heat operation only. These jumper selections are activated only when W1 is energized. In the heating mode, the blower control board delays blower operation for 30 seconds when W is energized at the thermostat upon call for heat. The blower continues to operate after the gas valve is de-energized for 180 seconds delayed off.

#### **CONTINUOUS FAN**

When the thermostat is set for "Continuous Fan" operation and there is no demand for heating or cooling, the blower control will provide 50 percent of the **COOL** CFM selected.

**NOTE** - With the proper thermostat and subbase, continuous blower operation is possible by closing the R to G circuit. Cooling blower delay is also functional in this mode.

#### DEHUMIDIFICATION

The blower control board includes an HUM terminal which provides for connection of a humidistat. The JW1 resistor on the blower control board must be cut to activate the HUM terminal. The humidistat must be wired to open on humidity rise. When the dehumidification circuit is used, the variable speed motor will reduce the selected air flow rate by 25 percent when humidity levels are high. An LED (D1) lights when the blower is operating in the dehumidification mode.

**NOTE** - This unit is not approved for installation as part of a zoning system.

	POWER CONNECTOR	-
<u> </u>		1350949-0
PIN	DESCRIPTION	X
1	JUMPER PIN I TO P	
2	120VAC LINE INPUT	ONLY "
3	CHASSIS GROU	ND DA
4	AC LINE	
5	AC LINE	
	TROL CONNECTOR	
	ADER AMP 770974-1	
PIN	DESCRIPTION	
1	Cl	
2	W/WI	7
3	C2	
4	DELAY	7
5	COOL	1
6	۲I	7
7	ADJUST	1
8	OUT -	1
9	0	1
10	BK/PWM	1
11	HEAT	
12	R	7
13	EM/W2	-
14	Y/Y2	1
15	G	1
16	OUT +	1

## Blower Data – LRP14HP

Model	Diaman Tan		Air Volum	e (cfm) at \	/arious Ext	ernal Stati	c Pressure	s - in. w.g.	
No.	Blower Tap	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8
	Tap 1 (Fan Only)	680	590	550	500	450	380		
	Tap 2 (Low Cooling)	890	830	800	760	710	680	640	600
LRP14HP24	Tap 3 (High Cooling)	1000	960	930	880	840	810	770	730
	<sup>1</sup> Tap 4 (Low Electric Heat)	890	830	800	760				
	<sup>1</sup> Tap 5 (High Electric Heat)					840	810	770	730
	Tap 1 (Fan Only)	680	640	600	570	530	490		
	Tap 2 (Low Cooling)	1100	1070	1050	1020	990	960	930	900
LRP14HP30	Tap 3 (High Cooling)	1180	1160	1130	1090	1070	1040	1010	960
	<sup>1</sup> Tap 4 (Low Electric Heat)	1100	1070	1050	1020				
	<sup>1</sup> Tap 5 (High Electric Heat)					1070	1040	1010	960
	Tap 1 (Fan Only)	860	810	760	710	660	590	550	490
LRP14HP36	Tap 2 (Low Cooling)	1300	1265	1235	1200	1165	1125	1015	1040
	Tap 3 (High Cooling)	1475	1450	1420	1375	1345	1310	1275	1190
	<sup>1</sup> Tap 4 (Low Electric Heat)	1300	1265	1235	1200				
	<sup>1</sup> Tap 5 (High Electric Heat)					1345	1310	1275	1190
	Tap 1 (Fan Only)	800	720	640	550	475	390	310	
	Tap 2 (Low Cooling)	1470	1410	1360	1300	1260	1210	1155	1095
LRP14HP42	Tap 3 (High Cooling)	1700	1650	1610	1575	1560	1480	1480	1390
	<sup>1</sup> Tap 4 (Low Electric Heat)	1470	1410	1360	1300				
	<sup>1</sup> Tap 5 (High Electric Heat)					1560	1480	1480	1390
	Tap 1 (Fan Only)	1165	1075	1000	930	850	790	760	670
	Tap 2 (Low Cooling)	1675	1630	1600	1540	1490	1440	1390	1300
LRP14HP48	Tap 3 (High Cooling)	1800	1770	1715	1690	1660	1610	1565	1500
	<sup>1</sup> Tap 4 (Low Electric Heat)	1675	1630	1600	1540				
	<sup>1</sup> Tap 5 (High Electric Heat)					1660	1610	1565	1500
	Tap 1 (Fan Only)	1400	1320	1260	1200	1120	1060	980	900
	Tap 2 (Low Cooling)	1920	1870	1820	1770	1720	1670	1450	1360
LRP14HP60	Tap 3 (High Cooling)	2240	2200	2140	2100	2060	2020	1980	1950
	<sup>1</sup> Tap 4 (Low Electric Heat)	1920	1870	1820	1770				
	<sup>1</sup> Tap 5 (High Electric Heat)					2060	2020	1980	1950

NOTE - All air data is measured external to unit without air filters.

<sup>1</sup> Taps 4 and 5 are used with Optional Electric Heat. Refer to Electric Heat nameplate for proper heat tap selection.

## Blower Data – LRP14AC

Model	Diama Tan		Air Volum	e (cfm) at V	/arious Ext	ernal Stati	c Pressure	s - in. w.g.	
No.	Blower Tap	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8
	Tap 1 (Fan Only)	610	560	525	485	430			
	Tap 2 (Low Cooling)	820	795	760	720	690	650	615	575
LRP14AC24	Tap 3 (High Cooling)	950	920	880	850	820	800	760	720
	<sup>1</sup> Tap 4 (Low Electric Heat)	820	795	760	720				
	<sup>1</sup> Tap 5 (High Electric Heat)					820	800	760	720
	Tap 1 (Fan Only)	850	820	780	745	710	680	630	590
	Tap 2 (Low Cooling)	1040	1000	970	935	900	875	845	815
LRP14AC30	Tap 3 (High Cooling)	1175	1145	1115	1080	1050	1015	990	945
	<sup>1</sup> Tap 4 (Low Electric Heat)	1040	1000	970	935				
	<sup>1</sup> Tap 5 (High Electric Heat)					1050	1015	990	945
	Tap 1 (Fan Only)	850	800	750	700	645	600	550	480
	Tap 2 (Low Cooling)	1245	1210	1175	1140	1100	1065	1025	975
LRP14AC36	Tap 3 (High Cooling)	1400	1370	1335	1300	1265	1220	1180	1150
	<sup>1</sup> Tap 4 (Low Electric Heat)	1265	1210	1175	1160				
	<sup>1</sup> Tap 5 (High Electric Heat)					1265	1220	1180	1150
	Tap 1 (Fan Only)	800	720	640	550	475	390	310	
	Tap 2 (Low Cooling)	1470	1410	1360	1300	1260	1210	1155	1095
LRP14AC42	Tap 3 (High Cooling)	1700	1650	1610	1575	1540	1480	1430	1390
	<sup>1</sup> Tap 4 (Low Electric Heat)	1630	1410	1360	1300				
	<sup>1</sup> Tap 5 (High Electric Heat)					1540	1480	1430	1390
	Tap 1 (Fan Only)	1145	1075	1000	930	850	790	740	670
	Tap 2 (Low Cooling)	1675	1630	1600	1540	1490	1440	1390	1300
LRP14AC48	Tap 3 (High Cooling)	1800	1770	1715	1690	1640	1610	1565	1500
	<sup>1</sup> Tap 4 (Low Electric Heat)	1675	1630	1600	1560				
	<sup>1</sup> Tap 5 (High Electric Heat)					1640	1610	1565	1500
	Tap 1 (Fan Only)	1400	1320	1260	1200	1120	1060	980	900
	Tap 2 (Low Cooling)	1920	1870	1820	1770	1720	1670	1450	1360
LRP14AC60	Tap 3 (High Cooling)	2240	2200	2140	2100	2060	2020	1980	1950
	<sup>1</sup> Tap 4 (Low Electric Heat)	1920	1870	1820	1770				
	<sup>1</sup> Tap 5 (High Electric Heat)					2060	2020	1980	1950

NOTE - All air data is measured external to unit without air filters.

<sup>1</sup> Taps 4 and 5 are used with Optional Electric Heat. Refer to Electric Heat nameplate for proper heat tap selection.

## Blower Data – LRP14GE / LRP14GX

Model			Air	Volume (o	:fm) at Va	rious Ext	ernal Sta	tic Press	ures - in.	w.g.	
No.	Blower Tap	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0
	Tap 1 (Fan Only)	610	560	525	485	430					
LRP14GE24 LRP14GX24	Tap 2 (Low Cooling)	820	795	760	720	690	650	615	575	540	470
	Tap 3 (High Cooling)	950	920	880	850	820	800	760	720	680	625
	Tap 1 (Fan Only)	850	820	780	745	710	680	630	590	550	515
LRP14GE30 LRP14GX30	Tap 2 (Low Cooling)	1040	1000	970	935	900	875	845	815	770	735
	Tap 3 (High Cooling)	1175	1145	1115	1080	1050	1015	990	945	900	860
	Tap 1 (Fan Only)	850	800	750	700	645	600	550	480	435	
LRP14GE36 LRP14GX36	Tap 2 (Low Cooling)	1245	1210	1175	1140	1100	1065	1025	975	920	845
	Tap 3 (High Cooling)	1400	1370	1335	1300	1265	1220	1180	1150	1060	875
	Tap 1 (Fan Only)	800	720	640	550	475	390	310			
LRP14GE42 LRP14GX42	Tap 2 (Low Cooling)	1470	1410	1360	1300	1260	1210	1155	1095	1000	940
	Tap 3 (High Cooling)	1700	1650	1610	1575	1540	1480	1430	1390	1340	1210
	Tap 1 (Fan Only)	1145	1075	1000	930	850	790	740	670	570	490
LRP14GE48 LRP14GX48	Tap 2 (Low Cooling)	1675	1630	1600	1540	1490	1440	1390	1300	1230	1125
	Tap 3 (High Cooling)	1800	1770	1715	1690	1640	1610	1565	1500	1460	1380
	Tap 1 (Fan Only)	1400	1320	1260	1200	1120	1060	980	900		
LRP14GE60 LRP14GX60	Tap 2 (Low Cooling)	1920	1870	1820	1770	1720	1670	1450	1360		
	Tap 3 (High Cooling)	2235	2195	2165	2130	2090	2060	2025	1985	1960	1940

NOTE - All air data is measured external to unit without air filters.

## Blower Data – LRP14GN

Model	Blower Tap		Air Vol	ume (cfm) at	Various Ext	ernal Static	Pressures -	in. w.g.
No.	Diowei Tap		0.1	0.2	0.3	0.4	0.5	0.6
	Tap 1 (Fan Only)		640	590	545	495	445	385
	Tap 2 Cooling (Low Static)		820	785	750	715	675	635
	Tap 3 Cooling (High Static)		920	880	855	825	790	755
LRP14GN24	Tap 4 Heating (Low Static)	CFM	925	890	865	830	795	765
		Rise (°F)	44	46	47	49	51	53
	Top E Lociting (Lligh Statio)	CFM	1005	970	940	910	880	855
	Tap 5 Heating (High Static)	Rise (°F)	41	42	43	45	46	48
	Tap 1 (Fan Only)		670	625	580	535	490	440
	Tap 2 Cooling (Low Static)		1020	985	955	920	890	860
	Tap 3 Cooling (High Static)		1125	1090	1055	1025	995	970
LRP14GN30		CFM	935	895	860	835	800	765
	Tap 4 Heating (Low Static)	Rise (°F)	44	45	47	49	51	53
		CFM	1020	990	955	925	895	865
	Tap 5 Heating (High Static)	Rise (°F)	40	41	43	44	46	47
	Tap 1 (Fan Only)		795	745	700	645	590	525
	Tap 2 Cooling (Low Static)		1250	1215	1180	1145	1115	1085
	Tap 3 Cooling (High Static)		1320	1290	1250	1225	1200	1170
LRP14GN36		CFM	935	890	855	815	770	725
	Tap 4 Heating (Low Static)	Rise (°F)	44	46	48	50	53	56
		CFM	1050	1010	970	935	895	860
	Tap 5 Heating (High Static)	Rise (°F)	39	40	42	44	46	47
	Tap 1 (Fan Only)		775	700	615	535	470	390
	Tap 2 Cooling (Low Static)		1460	1420	1380	1340	1300	1255
	Tap 3 Cooling (High Static)		1555	1525	1480	1445	1400	1365
LRP14GN42		CFM	1410	1370	1325	1285	1240	1200
	Tap 4 Heating (Low Static)	Rise (°F)	39	40	41	42	44	45
		CFM	1535	1495	1555	1415	1375	1335
	Tap 5 Heating (High Static)	Rise (°F)	35	36	37	38	39	41
	Tap 1 (Fan Only)		1065	1020	965	910	850	790
	Tap 2 Cooling (Low Static)		1665	1630	1595	1560	1530	1490
	Tap 3 Cooling (High Static)		1740	1705	1670	1635	1595	1545
LRP14GN48		CFM	1405	1370	1325	1290	1245	1205
	Tap 4 Heating (Low Static)	Rise (°F)	39	40	41	42	44	45
		CFM	1515	1480	1440	1405	1370	1325
	Tap 5 Heating (High Static)	Rise (°F)	36	37	38	39	40	41
	Tap 1 (Fan Only)		1240	1190	1125	1060	995	940
	Tap 2 Cooling (Low Static)		1885	1840	1800	1755	1715	1675
	Tap 3 Cooling (High Static)		1955	1915	1870	1835	1790	1760
LRP14GN60		CFM	1420	1365	1315	1265	1215	1155
	Tap 4 Heating (Low Static)	Rise (°F)	38	40	41	43	45	47
		CFM	1570	1520	1470	1420	1370	1320
	Tap 5 Heating (High Static)	Rise (°F)	35	36	37	38	40	41

NOTE - All air data is measured external to unit without air filters.

## Blower Data – LRP16GE / LRP16GX

#### LRP16GE24, LRP16GX24 Blower Performance

"ADJUST"				В	lower Co	ntrol Jum	per Spee	d Positior	าร			
Jumper	"	COOL" S	peed - cfr	n	"	'HEAT" S	peed - cfn	n	"CONT	INUOUS F	AN" Spe	ed - cfm
Setting	Α	В	С	D	Α	В	С	D	Α	В	С	D
+	1100	880	660	440	1100	1000	900	815	550	440	330	220
NORM	1000	800	600	400	1100	1000	900	815	500	400	300	200
	900	720	540	360	1100	1000	900	815	450	360	270	180

#### 0 through 0.80 in. w.g. External Static Pressure Range

#### LRP16GE36, LRP16GX36 Blower Performance

#### 0 through 0.80 in. w.g. External Static Pressure Range

"ADJUST"				В	lower Co	ntrol Jum	per Speed	d Positior	าร			
Jumper	"	"COOL" Speed - cfm				'HEAT" S	peed - cfn	n	"CONT	INUOUS F	AN" Spe	ed - cfm
Setting	Α	В	С	D	Α	В	С	D	Α	В	С	D
+	1540	1320	1100	880	1400	1200	1100	975	770	660	550	440
NORM	1400	1200	1000	800	1400	1200	1100	975	700	600	500	400
—	1260	1080	900	720	1400	1200	1100	975	630	540	450	360

#### LRP16GE48, LRP16GX48 Blower Performance

#### 0 through 0.80 in. w.g. External Static Pressure Range

"ADJUST"				В	lower Co	ntrol Jum	per Spee	d Positior	ıs			
Jumper	"COOL" Speed - cfm			"	'HEAT" S	peed - cfn	n	"CONT	INUOUS F	AN" Spe	ed - cfm	
Setting	Α	В	С	D	Α	В	С	D	Α	В	С	D
+	1980	1760	1540	1320	1350	1200	1100	1000	990	880	770	660
NORM	1800	1600	1400	1200	1350	1200	1100	1000	900	800	700	600
—	1620	1440	1260	1080	1350	1200	1100	1000	810	720	630	540

#### LRP16GE60, LRP16GX60 Blower Performance

#### 0 through 0.80 in. w.g. External Static Pressure Range

"ADJUST"				В	lower Co	ntrol Jum	per Spee	d Positior	าร			
Jumper	"	"COOL" Speed - cfm				'HEAT" S	peed - cfn	n	"CONT	NUOUS F	AN" Spe	ed - cfm
Setting	Α	В	С	D	Α	В	С	D	Α	В	С	D
+	2200	1980	1760	1540	1480	1380	1280	1180	1100	990	880	770
NORM	2000	1800	1600	1400	1480	1380	1280	1180	1000	900	800	700
—	1800	1620	1440	1260	1480	1380	1280	1180	900	810	720	630

NOTE - All air data is measured external to unit without air filters.

NOTE - 1st Stage airflow is 70% of 2nd Stage airflow (full capacity) in cooling mode. In heating mode, low stage airflow is optimized for a 40°F temperature rise.

## Blower Data – LRP16HP

#### LRP16HP24 Blower Performance

#### 0 through 0.80 in. w.g. External Static Pressure Range

"ADJUST"				В	lower Co	ntrol Jum	per Spee	d Positior	าร			
Jumper	"	COOL" S	peed - cfr	n	"	'HEAT" S	peed - cfn	n	"CONT	INUOUS F	AN" Spe	ed - cfm
Setting	Α	<sup>1</sup> B	С	D	Α	<sup>1</sup> B	С	D	Α	В	С	D
+	1100	880	660	440	1150	1035	690	690	550	440	330	220
NORM	1000	800	600	400	1000	900	600	600	500	400	300	200
—	900	720	540	360	1000	900	600	600	450	360	270	180

#### LRP16HP36 Blower Performance

#### 0 through 0.80 in. w.g. External Static Pressure Range

"ADJUST"		Blower Control Jumper Speed Positions										
Jumper	"	COOL" S	peed - cfr	n	6	HEAT" S	peed - cfr	n	"CONT	INUOUS F	AN" Spe	ed - cfm
Setting	Α	<sup>1</sup> B	С	D	Α	<sup>1</sup> B	С	D	Α	В	С	D
+	1430	1320	1100	880	1495	1380	1150	1150	715	660	550	440
NORM	1300	1200	1000	800	1300	1250	1000	1000	650	600	500	400
—	1170	1080	900	720	1300	1200	1000	1000	585	540	450	360

#### LRP16HP48 Blower Performance

#### 0 through 0.80 in. w.g. External Static Pressure Range

"ADJUST"				В	lower Co	ntrol Jum	per Spee	d Positior	IS			
Jumper	"	COOL" S	Speed - cfm "HEAT" Speed - cfm						"CONTI	NUOUS F	AN" Spe	ed - cfm
Setting	Α	<sup>1</sup> B	С	D	Α	<sup>1</sup> B	С	D	Α	В	С	D
+	1980	1760	1540	1320	2070	1840	1610	1610	990	880	770	660
NORM	1800	1600	1400	1200	1800	1600	1400	1400	900	800	700	600
—	1620	1440	1260	1080	1800	1600	1400	1400	810	720	630	540

#### LRP16HP60 Blower Performance

#### 0 through 0.80 in. w.g. External Static Pressure Range

"ADJUST"				В	lower Co	ntrol Jum	per Spee	d Positior	ıs			
Jumper	"	COOL" S	peed - cfr	n	6	'HEAT" S	peed - cfn	n	"CONT	INUOUS F	AN" Spe	ed - cfm
Setting	Α	<sup>1</sup> B	С	D	Α	<sup>1</sup> B	С	D	Α	В	С	D
+	2200	1980	1760	1540	2300	2070	1840	1840	1100	990	880	770
NORM	2000	1800	1600	1400	2000	1800	1600	1600	1000	900	800	700
	1800	1620	1440	1260	2000	1800	1600	1600	900	810	720	630

<sup>1</sup> Factory Settings.

NOTE - All air data is measured external to unit without air filters.

NOTE - 1st Stage airflow is 70% of 2nd Stage airflow (full capacity) in cooling mode.

#### DEFROST CONTROL CMC1

**NOTE** - For geographic areas that experience low temperature and high humidity conditions (below 32°F and above 80% RH), the defrost timer pin must be field set at installation to a 60 or 30 minute defrost interval in order to ensure reliable system operation while in heating mode.

LRP14HP and LRP16HP units are equipped with a defrost control that includes the combined functions of time/ temperature defrost control, defrost relay, diagnostic LEDs and a low voltage terminal strip. See figure 10.

The control provides automatic switching from call for heating to defrost mode and back. During the compressor cycle (call for defrost), the control accumulates compressor run time at 30, 60 or 90-minute field-adjustable intervals. If the defrost thermostat is closed when the selected compressor run time interval ends, the defrost relay is energized and the defrost begins.


The defrost timing is factory set to provide a 30-minute defrost interval. If the timing selector jumper is not in place, the control defaults to a 90-minute defrost interval. The maximum defrost period is 14 minutes and is not adjustable. See figure 10 for the location of the defrost interval timing pins.

A test option is provided for troubleshooting. The test mode may be started any time the unit is in the heating mode and the defrost thermostat is closed or jumpered. If the jumper is in the TEST position at power up, the control will ignore the test pins. When the jumper is placed across the TEST pins for 2 seconds, the control will enter the defrost mode. If the jumper is removed before an additional 5-second period has elapsed (7 seconds total), the unit will remain in defrost mode until the defrost thermostat opens or 14 minutes have passed. If the jumper is not removed until after the additional 5-second period has elapsed, the defrost will terminate and the test option will not function again until the jumper is removed and reapplied.

**NOTE** - On early defrost controls, the defrost timing jumper must be in the 90-minute defrost interval before testing the defrost mode or the control will not enter defrost test mode.

The defrost control includes a compressor delay function which cycles the compressor off for 30 seconds while going into and coming out of the defrost cycle. This function is activated when the jumper is removed from the compressor delay pins.

**NOTE** - The 30-second compressor delay is not functional when the TEST pins are jumpered.



#### **FIGURE 10**

The defrost thermostat (S6) is located on the outdoor coil, near the bottom of the coil, affixed to the  $\frac{3}{6}$ " stub. When the defrost thermostat senses a coil temperature of  $42^{\circ}$ F or cooler, the thermostat contacts close and send a signal to the defrost control to begin the defrost timing. The defrost thermostat also terminates the defrost when the coil distributor tube temperature warms to 70°F. The defrost control includes **HI-PS and LO-PS** terminals to receive signals from the unit high pressure switch and loss of charge switch.

During a single demand cycle, the defrost control locks out compressor operation after the fifth time that the circuit is interrupted by any pressure switch wired to the control. In addition, the diagnostic LEDs indicate a locked-out pressure switch after the fifth open pressure switch occurrence. Compressor operation remains locked out until power to the control is interrupted, then re-established, or until the jumper is applied to the TEST pins for 0.5 seconds.

**NOTE** - The defrost control ignores input from the loss of charge switch terminals as follows:

During the test mode;

During the defrost cycle;

During the 90-second start-up period;

During the first 90 seconds following a reversing valve switch between the heating and cooling modes.

EXCEPTION – If the TEST pins are jumpered and the 5-minute delay is being bypassed, the LO-PS terminal signal is not ignored during the 90-second start-up period.

The defrost control includes two diagnostic LEDs. LED codes indicate operating status. The diagnostics codes are given in table 3.

### **Defrost System**

#### Demand Defrost System

The demand defrost system measures differential temperatures to detect when the system is performing poorly because of ice build-up on the outdoor coil. The system "self-calibrates" when the defrost system starts and after each system defrost cycle. The demand defrost components on the control board are listed below. **NOTE**: The demand defrost system accurately measures the performance of the system as frost accumulates on the outdoor coil. This typically will translate into longer running time between defrost cycles as more frost accumulates on the outdoor coil before the board initiates defrost cycles.

#### **Defrost System Sensors**

Sensors connect to the defrost board through a field– replaceable harness assembly that plugs into the board. Through the sensors, the board detects outdoor ambient and coil fault conditions. As the detected temperature changes, the resistance across the sensor changes. Sensor resistance values can be checked by ohming across pins.

**NOTE**: When checking the ohms across a sensor, be aware that a sensor showing a resistance value that is not within the range shown, may be performing as designed. However, if a shorted or open circuit is detected, then the sensor may be faulty and the sensor harness will needs to be replaced.

Sensor	Temperature	Red LED	Pins / Wire
	Range °F (°C)	(DS1)	Color
Outdoor	-35 (-37) to	280,000 to	3 & 4
(ambient)	120 (48)	3750	(black)
Coil	-35 (-37) to	280,000 to	5 & 6
	120 (48)	3750	(brown)
NOTE: Senso	or resistance decr	eases as sensed	d temperature

#### TABLE 3. Sensor Temp. / Resistance Range

**NOTE**: Sensor resistance decreases as sensed temperature increases.




FIGURE 11. Defrost Control Board (2-Ton Units)

#### Coil Sensor

The coil temperature sensor considers outdoor temperatures below  $-35^{\circ}F$  ( $-37^{\circ}C$ ) or above  $120^{\circ}F$  ( $48^{\circ}C$ ) as a fault. If the coil temperature sensor is detected as being open, shorted or out of the temperature range of the sensor, the board will not perform demand or time/temperature defrost operation and will display the appropriate fault code. Heating and cooling operation will be allowed in this fault condition.

**NOTE**: The coil temperature probe is designed with a spring clip to allow mounting to the outside coil tubing. Coil sensor location is important for proper defrost operation.

#### Ambient Sensor

The ambient sensor considers outdoor temperatures below  $-35^{\circ}F$  ( $-37^{\circ}C$ ) or above  $120^{\circ}F$  ( $48^{\circ}C$ ) as a fault. If the ambient sensor is detected as being open, shorted or out of the temperature range of the sensor, the board will not perform demand defrost operation. The board will revert to time/temperature defrost operation and will display the appropriate fault code. Heating and cooling operation will be allowed in this fault condition.

**NOTE**: Within a single room thermostat demand, if 5-strikes occur, the board will lockout the unit. Control board 24 volt power "R" must be cycled "OFF" or the "TEST" pins on board must be shorted between 1 to 2 seconds to reset the board.

#### Defrost Temperature Termination Shunt (Jumper) Pins

The defrost board selections are: 50, 70, 90, and  $100^{\circ}F$  (10, 21, 32 and 38°C). The shunt termination pin is factory set at 50°F (10°C). If the temperature shunt is not installed, the default termination temperature is 90°F (32°C).

#### **Delay Mode**

The defrost system has a field-selectable function to reduce occasional sounds that may occur while the unit is cycling in and out of the defrost mode. When a jumper is installed on the DELAY pins, the compressor will be cycled off for 30 seconds going in and out of the defrost mode. Units are shipped with jumper installed on DELAY pins.

**NOTE:** The 30 second compressor delay feature (known as the quiet shift) <u>must</u> be deactivated during any unit performance testing. The feature is deactivated by removing the jumper located on the compressor delay pins on the control board mounted inside the unit control box. This feature is optional for the homeowner, but may impact testing performance.

#### **Defrost Operation**

The defrost control system has three basic operational modes: normal, calibration, and defrost.

- **Normal Mode**—The demand defrost system monitors the O line, to determine the system operating mode (heat/cool), outdoor ambient temperature, coil temperature (outdoor coil) and compressor run time to determine when a defrost cycle is required.
- Calibration Mode The board is considered uncalibrated when power is applied to the board, after cool mode operation, or if the coil temperature exceeds the termination temperature when it is in heat mode.

Calibration of the board occurs after a defrost cycle to ensure that there is no ice on the coil. During calibration, the temperature of both the coil and the ambient sensor are measured to establish the temperature differential which is required to allow a defrost cycle.

• **Defrost Mode** – The following paragraphs provide a detailed description of the defrost system operation.

#### **Defrost Cycles**

The control board initiates a defrost cycle based on either frost detection or time.

• **Frost Detection**—If the compressor runs longer than 30 minutes and the actual difference between the clear coil and frosted coil temperatures exceeds the maximum difference allowed by the control, a defrost cycle will be initiated.

**IMPORTANT** - The control board will allow a greater accumulation of frost and will initiate fewer defrost cycles than a time/ temperature defrost system.

• **Time**—If 6 hours of heating mode compressor run time has elapsed since the last defrost cycle while the coil temperature remains below 35°F (2°C), the control board will initiate a defrost cycle.

#### **Actuation**

When the reversing valve is de-energized, the Y1 circuit is energized, and the coil temperature is below  $35^{\circ}F$  (2°C), the board logs the compressor run time. If the board is not calibrated, a defrost cycle will be initiated after 30 minutes of heating mode compressor run time. The control will attempt to self-calibrate after this (and all other) defrost cycle(s).

Calibration success depends on stable system temperatures during the 20-minute calibration period. If the board fails to calibrate, another defrost cycle will be initiated after 45 minutes of heating mode compressor run time. Once the control board is calibrated, it initiates a demand defrost cycle when the difference between the clear coil and frosted coil temperatures exceeds the maximum difference allowed by the control OR after 6 hours of heating mode compressor run time has been logged since the last defrost cycle.

**NOTE:** If ambient or coil fault is detected, the board will not execute the "TEST" mode.

#### **Termination**

The defrost cycle ends when the coil temperature exceeds the termination temperature or after 14 minutes of defrost operation. If the defrost is terminated by the 14-minute timer, another defrost cycle will be initiated after 30 minutes of run time.

#### 5-Strike Lockout Feature

The internal control logic of the board counts the pressure switch trips only while the Y1 (Input) line is active. If a pressure switch opens and closes four times during a Y1 (Input), the control logic will reset the pressure switch trip counter to zero at the end of the Y1 (Input). If the pressure switch opens for a fifth time during the current Y1 (Input), the control will enter a lockout condition. The 5-strike pressure switch lockout condition can be reset by cycling OFF the 24-volt power to the control board or by shorting the TEST pins between 1 and 2 seconds. All timer functions (run times) will also be reset.

If a pressure switch opens while the Y1 Out line is engaged, a 5-minute short cycle will occur after the switch closes.

#### **Nominal Defrost Time Selection Input**

(Replaces High Stage Lock-In Temperature Selection Input) [BE1].

The nominal defrost time selection input is provided by the position of a selection shunt on the 0.100" P3 header. If the nominal defrost time shunt is not installed, the default nominal defrost time shall be 140 seconds. The controls shall be provided from the factory with the shunt installed in the 140 position. The nominal defrost time selection is used as the value for the Nom\_def\_time variable.

#### Position Definitions for P3 Header

- Connecting P3-1 and P3-2 will set the nominal defrost time to 140 seconds.
- Connecting P3-2 and P3-3 will set the nominal defrost time to 100 seconds.
- Connecting P3-3 and P3-4 will set the nominal defrost time to 60 seconds.
- Connecting P3-4 and P3-5 will set the nominal defrost time to 165 seconds.

[BE1] Modifying the function of the shunt on the P3 header to select the nominal defrost time. The high stage lock-in function is not needed for this unit since it is only single stage.

#### **Diagnostic LEDs**

The defrost board uses two LEDs for diagnostics. The LEDs flash a specific sequence according to the condition as shown in Table 4.

TABLE 4 Defrost Control Diagnostic LEDs

	e en la en Blagheeta	
Mode	Green LED (DS2)	Red LED (DS1)
No Power to Control	OFF	OFF
Normal Operation / Power to Control	Simultaneou	s Slow Flash
Anti-Short Cycle Lockout	Alternating	Slow Flash
Low Pressure Switch Fault	OFF	Slow Flash
Low Pressure Switch Lockout	OFF	ON
High Pressure Switch Fault	Slow Flash	OFF
High Pressure Switch Lockout	ON	OFF

#### **BLOWER COMPARTMENT**

Access panels can easily be removed for service.

#### **Blower Wheel**

Blower wheel size varies between models. See SPECIFI-CATIONS.

## A WARNING



Disconnect power from unit and wait at least five minutes to allow capacitors to discharge before attempting to adjust motor speed tap settings. Failure to wait may cause personal injury or death.

## **REFRIGERATION COMPONENTS**

### Compressor B1 – LRP14 Units

LRP14GE/GN and LRP14AC (-024 and -030 models) utilize a rotary compressor. All other LRP14 models utilize a scroll compressor. Compressors are energized by the K1 contactor found in the unit control box. Compressor specifications are found in the "ELECTRICAL DATA" section in this manual.

#### Compressor B1 – LRP16GE/HP Units

All LRP16GE units utilize a two-stage Copeland scroll compressor. Compressors are energized by the K1 contactor found in the unit control box. Compressor specifications are found in the "ELECTRICAL DATA" section in this manual.

## A WARNING

Electrical shock hazard. Compressor must be grounded. Do not operate without protective cover over terminals. Disconnect power before removing protective cover. Discharge capacitors before servicing unit. Failure to follow these precautions could cause electrical shock resulting in injury or death.

### Condenser Fan B4 / Fan Motor B3 - LRP14 Units


LRP14 series units are equipped with a constant torque blower motor. The constant torque motor is capable of maintaining a specified CFM throughout the external static range. Indoor fans are equipped with a permanent magnet constant torque motor. These motors remain energized and are controlled by 24V signals. For high static applications, use Tap 3 for cooling speed and Tap 5 for heating speed.

All LRP14 series units use single phase condenser fan motors. Specifications for the condenser fans are at the front of this manual. See figure 11 for fan and motor replacement dimensions.

#### Condenser Fan B4 / Fan Motor B3 – LRP16GE/HP Units

LRP16GE/HP units are equipped with a variable-speed direct-drive blower operated by a variable-speed ECM motor. The ECM motor maintains a specified air volume from 0 through 0.80 in. w.g. static range.

All LRP16GE/HP units use single phase condenser fan motors. Specifications for the condenser fans are at the front of this manual. See figure 11 for fan and motor replacement dimensions.



#### FIGURE 12

### Reversing Valve L1

Reversing valve L1 has a 24 volt solenoid coil which reverses refrigerant flow during unit operation in all LRP14HP and LRP16HP units. The reversing valve is in the refrigerant circuit vapor line. The reversing valve coil is energized during cooling demand and during defrost.

# Low Pressure Switch S79 (LRP14GE, AC, LRP16GE Units)

S79 is a N.C. auto-reset low pressure switch located on the suction line. The switch shuts off the compressor when suction pressure falls below the factory setting. The switch is ignored during the first 90 seconds of compressor start up and during defrost operation. On the LRP14/16 series units, the switch is set to open at  $25 \pm 5$  psi and close at  $40 \pm 5$  psi. S79 is not adjustable.

# Loss of Charge Pressure Switch S79 (LRP14HP-02 – LRP16HP Units)

The low pressure switch is an auto-reset N.C. switch that opens on pressure drop. The switch is wired into the defrost board low pressure terminals and is located on the liquid (high pressure) line . When suction pressure drops to 40 psig (275.8 kPa) the switch opens and the compressor is de-energized. When suction pressure rises to 90 psig (620.5 kPa) the pressure switch will close.

#### **High Pressure Switch S4**

S4 is a N.C. auto-reset high pressure switch located on the discharge line. The switch shuts off the compressor when discharge pressure rises above the factory setting. The switch on LRP14/16 series units is set to open at 590 + 10 psi and close at 418 + 10 psi. S4 is not adjustable.

#### Float Switch

A float switch is included with the downflow kit or can be ordered as an accessory (float switch is factory installed on the LRP16 series). The float switch is designed to prevent condensate water from overflowing the condensate pan due to a restriction in the condensate drain line. The float switch is field-installed in the condensate drain pan near the drain exit (float switch is factory installed on the LRP16 series). Refer to the installation instruction for the float switch kit or the downflow kit for location and cutting of the red wire located in the blower compartment.

#### **ELECTRIC HEAT**

### **Matchups and Ratings**

Matchups and ratings are listed with "ELECTRICAL DATA".

## **Electric Heat Components**

See figure 12 for electric heat parts arrangement.

### Limit Switches 1, 2, 3 and 4

Limit switches 1, 2, 3 and 4 are N.C. auto-reset high temperature limits located on the electric heat vest panel. Each heating element is wired in series with a high temperature limit. When the limit opens, the corresponding heating element is de-energized. All other heating elements remain energized. The limits will automatically close when temperatures return to normal. Limit rating will be on front side.

## Heating Element HE1 through HE4

Heating elements are composed of helix-wound bare nichrome wire exposed directly to the air stream. The elements are supported by insulators mounted to the wire frame. Each element is energized independently by a corresponding relay located on the heat vest panel. Once energized, heat transfer is instantaneous.




FIGURE 13

## Terminal Strip TB2 PHK-05, -07, -10

All heating elements require either a second-line voltage power source or the use of the single-point power connection kit. For electric heat sections without circuit breakers or fuses, line voltage connections are made to terminal strip TB2.

### Sequencer Relays 1 and 2

Relays 1 and 2 are N.O. sequencer relays with a resistive element for a coil and bi-metal disk which actuates the contacts. The relays are located on the electric heat vest panel and are energized by a 24V heating demand (W1 and W2) via jack/plug P2 which is used to connect electric heat to the blower control circuit. When energized, the internal resistance heats the bi-metal disk causing the contacts to close. When the relay is de-energized the disk cools and the contacts open. The relays energize different stages of heat, as well as the blower. The blower is always first on and last off. **NOTE** - As of 2015, all electric heaters must be equipped with a second relay to break the line voltage on the return side so that a path for the electrical voltage is broken on both sides if an element goes to ground.

## Circuit Breaker CB1 and CB2 (option) PHK-15, -20

Line voltage connections are made to circuit breakers CB1 and CB2 in electric heat sections with circuit breakers. Table 2 shows amp rating for each circuit breaker used. Twopole circuit breakers are used.

TABLE 5
---------

Circuit Breakers		
UNIT	CB1 AMPS	CB2 AMPS
PHK15CP	60 AMPS	30 AMPS
PHK20CP	60 AMPS	60 AMPS

#### GAS HEAT

#### Gas Valve (GV1) LRP16GE Units

The LRP16GE uses a gas valve manufactured by White-Rodgers. The valve is two-stage internally redundant to assure safety shut off. If the valve must be replaced the same type valve must be used. The valve can be converted to LP (see options gas specifications for LP kit) and is adjustable on both high and low fire.

24VAC and gas control knob / switch are located on top of the valve. Terminals on the gas valve are connected to wires from the ignition control (A3). Inlet and outlet taps are located on the valve.




FIGURE 14

#### **Control System Diagnostics**

LED Status	Flashing Rate	Fault Description
Slow Flash	One flash per second	Normal operation: No call for heat
Fast Flash	Two flashes per second	Normal operation: Call for heat
2 Flash	Two flashes in 1 second with 1-second pause	System lockout: Failed to detect or sustain flame
3 Flash	Three flashes in 1.5 seconds with 1-second pause	Pressure switch senses incorrect pressure or gas valve coil is open
4 Flash	Four flashes in 2 seconds with 1-second pause	High limit or rollout switch open
5 Flash	Five flashes in 2.5 seconds with 1-second pause	Flame sensed and gas valve not energized
Steady	_	Internal failure: Micro-controller failure; self-check

#### **TABLE 6. Fault Codes**

#### CHARGING

#### 

As with any mechanical equipment, contact with sharp sheet metal edges can result in personal injury. Take care while handling this equipment and wear gloves and protective clothing.

For maximum performance of the cooling system, the operating temperatures and pressure should be checked and subcooling determined at Standard ARI test conditions of 82° F outdoor temperature / 80° F indoor dry bulb / 67° F indoor wet bulb.

For maximum performance of the heat pump, the operating temperatures and pressure should be checked and subcooling determined at Standard ARI test conditions of 47° F outdoor temperature / 70° F indoor dry bulb.

If subcooling measurement deviates, refrigerant charge should be adjusted accordingly for maximum performance.

AC Unit Cooling System Performance Values - LRP14		
Model	Suction Superheat + / - 3°	Liquid Subcooling + / - 2°
2 Ton		10
2.5 Ton		14
3 Ton	13	
3.5 Ton	12	
4 Ton	14	
5 Ton	17	
Based on outdoor ambient temperature of 82º F and indoor entering air of 80º F db, 67º F wb.		

## TABLE 7

Heat Pump Cooling System Performance Values - LRP14HP / LRP16HP		
Model	Suction Superheat + / - 3°	Liquid Subcooling + / - 2°
2 Ton	18	
2.5 Ton	16	
3 Ton	14	
3.5 Ton		9
4 Ton		8
5 Ton		5
Based on outdoor ambient temperature of 82° F and indoor		

entering air of 80° F db, 67° F wb.

#### TABLE 9

Heat Pump Heating System Performance Values - LRP14HP / LRP16HP		
Model	Liquid Subcooling + / - 2°	
2 Ton	25	
2.5 Ton	15	
3 Ton	11	
3.5 Ton	22	
4 Ton	24	
5 Ton	28	
Paged on outdoor ambient temporature of 47% E and indeor		

Based on outdoor ambient temperature of 47° F and indoor entering air of 70° F db.

#### TABLE 10

Unit Cooling System Performance Values - LRP16GE		
Model	Liquid Subcooling + / - 3°	
2 Ton	10	
3 Ton	12	
4 Ton	10	
5 Ton 9		
Based on outdoor ambient temperature of 82° F and indoor entering air of 80° F db, 67° F wb.		

#### MAINTENANCE

The heating and air conditioning system should be inspected and maintained twice each year (before the start of the cooling and heating seasons) by a licensed professional HVAC technician. The technician is expected to check the following items. **These checks may only be conducted by a licensed professional HVAC technician**.

- Inspect component wiring for loose, worn or damaged connections. Check for any rubbing or pinching of wires. Confirm proper voltage plus amperage of outdoor unit.
- 2 Check the cleanliness of fan and blade condition (cracks) and clean or replace them, if necessary.
- 3 Inspect drain pan for debris and clean as necessary.
- Inspect the condition of refrigerant piping and confirm that pipes are not rubbing copper-to-copper. Also, check the condition of the insulation on the refrigerant lines. Repair, correct, or replace as necessary.

- 5 Test capacitor. Replace as necessary.
- 6 Inspect contactor contacts for pitting or burn marks. Replace as necessary.
- 7 Check fan motor for worn bearings/bushings. Replace as necessary.
- 8 Inspect and clean coils, if necessary and note any damage to coils or signs of leakage.

#### Filters

 Internal filter kits containing filter rails for 1 in. thick filters are available. Filters are not provided and must be field supplied. A filter is required, whether installed in the unit, in the ductwork or behind a filter grill in the conditioned area.

**NOTE** - If PCO is installed, an internal filter kit is not recommended.

2 - Filters should be inspected monthly. Replace disposable filters or clean permanent-type filters as necessary. Dirty filters are the most common cause of inadequate heating or cooling performance. Replace existing filter with a filter of like type and size. DO NOT replace a permanent-type filter with a disposable filter. Install new/clean filters with the arrows on the side pointing in the direction of airflow.

# Healthy Climate® Photocatalytic Oxidation (PCO) Air Purification Accessory (LRP16 Series Only)

1 - The Healthy Climate® PCO cartridge and UVA lamp require annual replacement. An annual maintenance kit is available that includes the PCO cartridge and UVA lamp. More frequent replacement may be required in applications with heavier dust or dirt loads or in applications where a lower MERV filter is installed before the Healthy Climate® PCO cartridge. The field supplied filter should be changed at least annually, or according to the manufacturers recommended replacement cycle.

### General System Test with System Operating

- Perform a general system test. Turn on the air conditioner to check operating functions such as the startup and shutoff operation. Check for unusual noises or odors, and measure indoor/outdoor temperatures and system pressures as needed. Check the refrigerant charge per the charging sticker information on the unit.
- 2 Refer to the nameplate to determine the correct temperature rise for all gas units (GE / DF).
- 3 Verify that system total static pressure and airflow settings are within specific operating parameters.
- 4 Verify correct temperature drop across indoor coil.

### POST START-UP CHECKLIST (GAS)

After the control circuit has been energized and the heating section is operating, make the following checks:


- 1 Use soap solution to check for gas leaks in the unit piping as well as the supply piping.
- 2 Check the supply gas pressure. It must be within the limits shown on rating nameplate. Supply pressure

should be checked with all gas appliances in the building at full fire. At no time should the supply gas pressure exceed 10.5 inches w.c., nor drop below 5.0 inches w.c. for natural gas units. For propane gas, supply gas pressure should not drop below 11 inches w.c. If gas pressure is outside these limits, contact your gas supplier for corrective action.

- 3 Check for correct manifold gas pressures. See Check and Adjust Manifold Pressure.
- 4 Adjust temperature rise to the range specified on the rating plate.

#### Check and Adjust Manifold Pressure

After line pressure has been checked and adjusted, check manifold pressure. Refer to figure 14 for location of manifold pressure adjustment screw and pressure tap outlet.




#### **FIGURE 15**

The gas valve is factory set and should not require adjustment. See the table below for pressures. The gas valve should completely and immediately cycle off in the event of gas or power failure. The manual shut-off knob or switch can be used to immediately shut off gas supply.

Manifold Pressure " w.c.		
1st Stage Heat	Natural	2.0 ± 0.3
	LP	5.6 ± 0.3
2nd Stage Heat	Natural	3.5 ± 0.3
	LP	10.0 ± 0.5

## **IMPORTANT**



- Connect a test gauge to the outlet pressure tap on the gas valve. Start the unit and allow five minutes for the unit to reach steady state.
- 2 While waiting for the unit to stabilize, notice the flame. The flame should be stable without flashback and should not lift from the burner head. Natural gas should burn blue. L.P. gas should burn mostly blue with some orange streaks.

- 3 After allowing the unit to stabilize for five minutes, record the manifold pressure.
- 4 Disconnect heating demand as soon as an accurate reading has been obtained.


#### Proper Gas Flow (Approximate)

Final first-stage and second-stage manifold pressures must be within the allowable ranges for the gas being used. For Natural Gas: Check the furnace rate by observing gas meter, making sure all other gas appliances are turned off. The test hand on the meter should be timed for at least one revolution. Note the number of seconds for one revolution. BTU/HR = Cubic Feet Per Revolution X 3600 X Heating Value

INPUT No. Seconds Per Revolution

The heating value of your gas can be obtained from your local utility.


**For LP/Propane Gas:** The only check for the output rate is to properly adjust the manifold pressure using a manometer. Typical manifold setpoint for installations at altitudes from 0 to 4500 feet above sea level is 10.0 inches W.C.



# Wiring Diagrams and Sequence of Operation LRP14HP Unit Wiring Diagram – Constant Torque Blower

FIGURE 16

#### LRP14AC Unit Wiring Diagram – Constant Torque Blower



**FIGURE 17** 

#### LRP14GE Unit Wiring Diagram – Constant Torque Blower






FIGURE 18




LRP16GE Wiring Diagram


FIGURE 19




**FIGURE 20** 




**FIGURE 21** 



**FIGURE 22** 



**FIGURE 23** 



Page 45

#### SEQUENCE OF OPERATION – SINGLE-STAGE COM-PRESSOR

**NOTE** - The combustion air inducer is energized for 30 seconds at a Y1 call for cooling to clear warm humid air out of the heat exchanger.

#### Cooling

- Internal thermostat wiring energizes terminal "O" by cooling mode selection, energizing reversing valve L1.
- 2 Cooling demand initiates at Y1 in the indoor thermostat.
- 3 24VAC from Y1 energizes compressor contactor K1.
- 4 K1-1 closes energizing compressor B1 and outdoor fan motor B4.
- 5 Compressor B1 and outdoor fan B4 begin immediate operation.
- 6 6- Evaporator blower B3 begins operation.
- 7 When cool demand is satisfied, "Y1" in the indoor thermostat de-energizes K1 contactor. K1-1 opens de-energizing compressor B1 and outdoor fan B4. Evaporator blower B3 de-energizes after 90 seconds of time delay.
- 8 Terminal "O" is de-energized when internal thermostat is out of cool mode, de-energizing reversing valve L1.

### First Stage Heat Pump

- 1 Heating demand initiates at "Y1" in the thermostat.
- 2 24VAC energizes compressor contactor K1.
- 3 K1-1 closes energizing compressor B1 and outdoor fan B4.
- 4 Evaporator blower B3 energizes after 5 seconds.
- 5 When heat demand is satisfied, Y1 in the indoor thermostat de-energizes K1. K1-1 and K1-2 open and deenergizes compressor B1 and outdoor fan B4.
- 6 Evaporator blower B3 de-energizes after 90 seconds.

### Second Stage Auxiliary Heat

1 - Heating demand initiates at "Y1" and "W" in the thermostat. "W" can either be strip heat in a HP unit or gas burners in a DF unit.

#### **Emergency Heat**

1 - Emergency heat is energized by the room thermostat through "W".

### Defrost Mode

- During heating operation when liquid line temperature drops to 42F or lower defrost switch S6 closes.
- 2 Defrost control CMC1 begins timing. If defrost thermostat S6 remains closed at the end of 30, 60 or 90 minute period, defrost control energizes and defrost begins

**NOTE** - On early defrost controls, the defrost timing jumper must be in the 90-minute defrost interval before testing the defrost mode or the control will not enter defrost test mode.

- 3 During defrost CMC1 energizes the reversing valve L1 and de-energizes the outdoor fan B4. If the compressor delay jumper is set, the compressor will turn off for 30 seconds while the reversing valve shifts either in or out of defrost mode.
- 4 Defrost continues for 10 minutes or until defrost thermostat switch S6 opens (S6 will open when liquid line temperature reaches 70°). When defrost thermostat switch opens, defrost control CMC1 loses power and resets.
- 5 When CMC1 resets, reversing valve L1 is deenergized while outdoor fan B4 is energized.

### Gas Heat

- 1 Heating demand W1 initiates at the indoor thermostat.
- 2 Assuming all safety circuits are closed (with the exception of the pressure-prove switch open), A3 energizes the combustion air inducer blower B6. When the N.O. combustion air inducer pressure-prove switch S18 closes, a pre-purge period of 30 seconds follows.
- 3 Ignition control A3 begins spark and energizes gas valve GV1.
- 4 Gas valve GV1 opens. When flame is sensed, spark stops.
- 5 After 30 seconds, ignition control A3 energizes circulating air blower B3.
- 6 When heat demand is satisfied, the indoor thermostat de-energizes control A3 which deenergizes gas valve GV1 and combustion air inducer blower B6. Circulating air blower B3 runs for a designated period of 90 seconds.

#### SEQUENCE OF OPERATION – TWO-STAGE COM-PRESSOR

The two-stage scroll compressor operates much like the standard scroll compressor. The two-stage compressor steps between low capacity and high capacity as required to meet cooling demand. The steps occur when gas is bypassed through a vent port in the first suction pocket. This bypassing of gas allows the compressor to operate at low capacity if thermostat demand allows, creating a more cost effective and efficient compressor. Full capacity is achieved by blocking the vent port with a slider ring. The slider ring (vent port cover) is controlled by a 24VDC internal solenoid in the open position allowing low capacity. When energized the internal solenoid closes the slider ring, blocking the vent port and bringing the compressor to full capacity.

Stepping can occur during a single thermostat demand as the motor runs continuously while the compressor steps from low to full capacity. First and second stage cooling operate independent of each other and can modulate back and forth according to the thermostat demand.

#### First Stage Cooling (Low Capacity)

- 1 Cooling demand initiates at Y1 at the thermostat.
- 2 Voltage from terminal Y passes through S4 high pressure switch, energizes K1 compressor contactor, passes through the low pressure switch (S87) and returns to common side of the 24VAC power.
- 3 K1 closes, energizing B1 compressor and B4 outdoor fan.
- 4 Solenoid L34 is not energized so the slider ring remains open, limiting compressor to low capacity.

#### Second Stage Cooling (High Capacity)

Compressor is operating in first stage cooling. Second stage thermostat demand sends voltage to rectifier plug D4. D4 converts the AC voltage to DC voltage and energizes L34 unloader solenoid. L34 closes the slider ring, allowing the compressor to operate at high capacity.

## LRP14GN – Heating Components and Operation

#### Gas Valve






FIGURE 25. LRP14GN Gas Valve

The gas valve is factory set and does not require adjustment. See the table below for pressures. The gas valve should completely and immediately cycle off in the event of gas or power failure. The manual shut-off knob or switch can be used to immediately shut off gas supply.

Manifold Pressure	2.7 - 3.1" w.c.
(non-adjustable)	2.7 - 3.1 w.c.






#### **Manifold Pressure**

A unit's Manifold Pressure is the product of the Signal Pressure x the Gas Valve's Amplification Factor (MP =  $\Delta P \times AF$ ). If the manifold pressure is not within specification, it will be helpful to determine if it is the Signal Pressure or the Amplification Factor that is the culprit. The amplification factor is 4.0 ± 20% (so 3.2 - 4.8). Typical gas valves that we have encountered during development seem to range between 3.8 and 4.2.

#### Condition: Signal Pressure Amplification Factor Manifold Pressure Notes

- Nominal 0.72 4.0 2.9
- Low Amp 0.72 3.8 2.7 Not full AF tolerance range
- High Amp 0.72 4.2 3.0 Not full AF tolerance range
- Low Signal 0.67 4.0 2.7
- High Signal 0.77 4.0 3.1
- Both Low 0.67 3.8 2.6 Not full AF tolerance range
- Both High 0.77 4.2 3.2 Not full AF tolerance range



### FIGURE 28. Typical Heating Parts Arrangement Post-Start Checklist

After the entire control circuit has been energized and the heating section is operating, make the following checks:

- 1 Check for gas leaks, using soapy solution, in the unit piping as well as the supply piping.
- 2 Check the supply gas pressure. It must be within the limits shown on the rating plate. Supply pressure should be checked with all gas appliances in the building at full fire. At no time should the standby gas pressure exceed 13" w.c., nor the operation pressure drop below 5" w.c. for natural gas units. If gas pressure is outside these limits, contact the gas supplier for corrective action.

- 3 Select indoor blower speed tap, which provides a temperature rise within the range specified on the rating plate.
- 4 Verify manifold gas pressure

**NOTE**: For purpose of this measurement, the minimum permissible gas supply pressure is 5" w.c. for natural gas.

- a. Slide the gas valve switch to the "OFF" position (see Figure 24).
- b. Remove plug on valve marked "OUTLET PRESSURE."
- c. Install a water manometer.

d. Slide the gas valve switch to the "ON" position and initiate a call for heat. During steady state operation, manifold pressure should be:

Manifold Pressure (non-adjustable)	2.7 - 3.1" w.c.
(	

- e. After verifying pressure, turn gas off, remove manometer fitting, and replace pipe plug and regulator cap.
- f. Put unit in operation and check plug for leaks using soapy solution.




FIGURE 29. Gas Valve, Manifold and Heat Exchanger Assembly

ALTERNATE COMBUSTION AIR ORIFICE OPTIONS FOR RESOLVING RESONANCE ISSUES WITH ULN PACKAGE UNITS					
BTU	COMBUSTION AIR ORIFICE OPTION	<b>ORIFICE SIZE</b>	ORIFICE ID STAMP	PART NUMBER	
54k	Factory Original	0.970	23	22J96	
54k	Alternative Option 1	0.969	08	19X35	
54k	Alternative Option 2	0.937	15	19X37	
72k	Factory Original	1.140	24	22J97	
72k	Alternative Option 1	1.125	03	19X31	
72k	Alternative Option 2	1.105	12	21U24	




FIGURE 30. Wiring Diagram – Single Phase CT