

SERVICE AND APPLICATION NOTES

110000
11-6-2023

EL180UH080NE48B Nameplate Error

In a recent audit, Lennox discovered inaccurate information on the nameplate of this model. The manifold pressure setting and the line pressure for this model were incorrect.

The manifold pressure was listed as 3.4" W.C and should be 0.05" W.C.

The Gas Supply Line Pressure Minimum/Maximum was listed as 13.0/4.5 and should be 10.5/4.5.

Units with the incorrect nameplate do not require any action on your part. All units are factory adjusted to 0.05" WC and the unit will operate at that pressure. The valves are not permitted to be adjusted.

If you are at a job and notice the manifold pressure setting on the nameplate is incorrect, please leave a copy of this bulletin as a notice to future service technicians.

If you have any questions please contact Lennox Technical Support at (800) 453-6669.

LENNOX		ASSEMBLED
DALLAS, TEXAS		IN THE USA
M/N	EL180UH080NE48B-05	
S/N	00001	
HEATING DATA		
EQUIPPED FOR USE WITH NATURAL GAS		
INPUT (BTUH)	80,000	
OUTPUT (BTUH)	64,000	
MANIFOLD PRESSURE (IN. W.C.)	0.05	
GAS SUPPLY LINE PRESS (MAX/MIN IN. W.C.) FOR PURPOSE OF INPUT ADJUSTMENT	10.5/4.5	

