



SERVICE AND APPLICATION NOTES

MS-17-01

February 1, 2017

Sleep Button on Wireless Remote for Mini-Split Systems

AFFECTED UNITS:

Wireless Remote M0STAT60Q-1 Shipped with Indoor Units Matched with MPA, MPB and MLA Outdoor Units.

ISSUE:

The Wireless Remote M0STAT60Q-1 User Guide (507560-03, dated 8/2015) included with the indoor unit has an incorrect statement concerning the function of the Sleep Button.

Incorrect Statement: (statement is located on page 3 of the user guide)

Sleep button. Press to activate "night-mode". This will automatically increase (cooling) or decrease (heating) the setpoint 2°F (1°C) per hour for the first two hours. The modified setpoint will be set for five hours. **After seven total hours the indoor unit will resume the previously set setpoint.**

Correct Statement:

Sleep button. Press to activate "night-mode". This will automatically increase (cooling) or decrease (heating) the setpoint 2°F (1°C) per hour for the first two hours. The modified setpoint will be set for five hours. **After seven total hours the indoor unit will shut-off. The system will remain off until the "On" button on the wireless remote is pressed.**

The statement in the Product Specifications (Engineering Handbook) is correct. The statement has been corrected in the user guide (dated 1/2017) and is available on LennoxPROs. The corrected wireless remote user guide will be included in units manufactured in the near future.

During installation, please advise the homeowner of this incorrect statement and explain the proper operation of the wireless remote. We apologize for any inconvenience this issue may have caused.